


# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	1	1   1   0   8	15650
SYS	PERMIT NUMBER	SET	YEAR MO.	EID

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE	UNITS					
316164024 FEC. COLI	REPORTED	<2	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
DLY AVG	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI	REPORTED	<2	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
IND GRAB	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW	REPORTED	0.65	MGD	0	02	CONT	11	CONT
DLY AVG	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB	REPORTED	<2.1	MG/L	0	11	2/WEEK	03	GRABPKLOAD
DLY AVG	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY	REPORTED	1.66	NTU	0	11	2/WEEK	03	GRABPKLOAD
30DAY AVG	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA	
EXPIRATION OF OPERATOR CERTIFICATE	PERMITTED				01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED	A	LETTER	0	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.  
Walnut Creek WWTP transferred reclaimed water for 31 days.

<small>CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE</small>		NAME	SIGNATURE	DATE
		Mike Welch		1   1   0   9   0   9
TELEPHONE NUMBER		PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2	9   7   2	0   1   0   1	Greg Meszaros, Director	1   1   0   9   0   9
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY


# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 2 of 3



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	1   1   0   8 YEAR MO.	15651 EID
------------	--------------------------------	----------	---------------------------	--------------

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE	UNITS					
000085342 TRANSFER DAYS MON	REPORTED	30	DAY	0	01		01	
	PERMITTED				01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	<21	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	200.000			14	1/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	500	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	800.000			14	1/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	4.49	MGD	0	02	CONT	11	CONT
	PERMITTED				14	1/WEEK	02	GRAB
800821024 BOD CARB DLY AVG	REPORTED	<2.4	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	15.000			14	1/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		NA	
	PERMITTED				01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	DATE	0	01		NA	
	PERMITTED				01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, PA ID TX0071889. South Austin Regional WWTP transferred reclaimed water for 30 days.

CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1   1   0   9   0   9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1   1   0   9   0   9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY




# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

Page 3 of 3

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	1   1   0   8 YEAR MO.	15652 EID
------------	--------------------------------	----------	---------------------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**  
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS  
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE					
500507124 FLOW DAILY AVG	REPORTED	4.99	0	01		01	
	PERMITTED			01	NA	01	NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	0	01		NA	
	PERMITTED			01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/11/12	0	01		NA	
	PERMITTED			01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	0	01		NA	
	PERMITTED			01	01	NA	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

### COMMENTS AND EXPLANATIONS (Reference all attachments here)

Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 31 days and South Austin Regional WWTP transferred reclaimed water 30 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

NAME		SIGNATURE		DATE	
Mike Welch				1   1   0   9   0   9	
PLANT OPERATOR		PLANT OPERATOR		YEAR MO. DAY	
5   1   2   9   7   2   0   1   0   1		Greg Meszaros, Director		1   1   0   9   0   9	
NUMBER		EXECUTIVE OFFICER		EXECUTIVE OFFICER	
				YEAR MO. DAY	