

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	1	1 1 0 3	15650
SYS	PERMIT NUMBER	SET	YEAR MO.	EID

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE	UNITS					
316164024 FEC. COLI DLY AVG	REPORTED	<2	#/100 ML	0	11		03	
	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	<2	#/100 ML	0	11		03	
	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	0.27	MGD	0	02		11	
	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	<2.0	MG/L	0	11		03	
	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	2.27	NTU	0	11		03	
	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		01	
	PERMITTED				01	NA	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01		01	
	PERMITTED				01	NA	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		01	
	PERMITTED				01	NA	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.
Walnut Creek WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

NAME

SIGNATURE

DATE

Mike Welch

Mike Welch

1 | 1 | 0 | 4 | 0 | 7

TELEPHONE NUMBER

PLANT OPERATOR

PLANT OPERATOR

YEAR MO. DAY

5 | 1 | 2 | 9 | 7 | 2 | 0 | 1 | 0 | 1

Greg Meszaros, Director

Greg Meszaros

1 | 1 | 0 | 4 | 0 | 7

AREA CODE NUMBER

EXECUTIVE OFFICER

EXECUTIVE OFFICER

YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

Page 2 of 3



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	1 1 YEAR	0 3 MO.	15651 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		VALUE	UNITS				
000085342	REPORTED	31	DAY	0	01	01	
TRANSFER	PERMITTED				01	01	NA
DAYS MON	REPORTED						
316164024	REPORTED	<2	#/100 ML	0	11	03	
FEC. COLI	PERMITTED	200.000			11	03	GRABPKLOAD
DLY AVG	REPORTED	8	#/100 ML	0	11	03	
316164030	PERMITTED	800.000			11	03	GRABPKLOAD
FEC. COLI	REPORTED	2.09	MGD	0	02	11	
IND GRAB	PERMITTED				02	11	CONT
500507124	REPORTED	3.1	MG/L	0	11	03	
FLOW	PERMITTED	15.000			11	03	GRABPKLOAD
DLY AVG	REPORTED	WW0011708	NUMBER	0	01	01	
800821024	PERMITTED				01	01	NA
BOD CARB	REPORTED	12/05/12	DATE	0	01	01	
DLY AVG	PERMITTED				01	01	NA
NUMBER	REPORTED	B	LETTER	0	01	01	
OF OPERATOR	PERMITTED				01	01	NA
CERTIFICATE	REPORTED						
EXPIRATION	PERMITTED						
OF OPERATOR	REPORTED						
CERTIFICATE	PERMITTED						
CLASS	REPORTED						
OF OPERATOR	PERMITTED						
CERTIFICATE	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1 1 0 4 0 7
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1 1 0 4 0 7
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

Page 3 of 3



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	1 1 0 3 YEAR MO.	15652 EID
------------	--------------------------------	----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE	UNITS					
500507124 FLOW	REPORTED	2.35	MGD	0	01		01	
DAILY AVG	PERMITTED				01	NA	01	NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		01	
EXPIRATION OF OPERATOR CERTIFICATE	PERMITTED				01	NA	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01		01	
	PERMITTED				01	NA	01	NA
	REPORTED	A	LETTER	0	01		01	
	PERMITTED				01	NA	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 31 days and South Austin Regional WWTP transferred reclaimed water 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

TELEPHONE NUMBER 5 1 2 9 7 2 0 1 0 1	NAME Mike Welch	SIGNATURE 	DATE 1 1 0 4 0 7
	PLANT OPERATOR Greg Meszaros, Director	PLANT OPERATOR 	YEAR MO. DAY 1 1 0 4 0 7
	EXECUTIVE OFFICER	EXECUTIVE OFFICER 	YEAR MO. DAY