

DMR Copy of Record

Permit

Permit #: TX0034207
Major: ☒

Permittee: AUSTIN,CITY OF
Permittee Address: 1700' SW INTX USHWY 183/FM 620
AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP
Facility Location: 1700' SW INTX USHWY 183 FM 620
WILLIAMSON COUNTY
AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge: 001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 01/01/11 to 01/31/11

DMR Due Date: 02/20/11

Status: NetDMR Validated

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	6.6					19 - mg/L	08/30 - Eight Every Month	GR - GRAB
					Permit Req.					>=	4 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.6			=	7.1	12 - SU	09/30 - Nine Per Month	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	02/DM - Twice Every Month	GR - GRAB
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	11.5		26 - lb/d			=	3.4	=	5.3	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV		26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	1.1		26 - lb/d			=	0.3	=	0.4	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV		26 - lb/d			<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.35	=	0.69	03 - Mgal/d							99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							99/99 - Continuous	TM - TOTALZ
					Value NODI													
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample									=	0.06	19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.									<=	.1 INST MAX	19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI													
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1					19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.					>=	1 MO MIN					19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI													
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	8		26 - lb/d			<	2.4	=	2.9	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV		26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2011-02-14 09:36 (Time Zone: -06:00)