

Permit

Major: ☐

Permittee:	AUSTIN,CITY OF
Permittee Address:	1700' SW INTX USHWY 183/FM 620 AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Status: NetDMR Validated

P = 2-HOUR PEAK.11459-001

First Name: Greg
Last Name: Meszaros

Title:	Director
--------	----------

Telephone: 512-972-0101

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV	Req Mon DAILY MX	03 - MGD								0	Continuous	TOTALZ
					Value NODI													99/99 - Continuous	TM - TOTALZ
					Sample														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.04	19 - mg/L		0	01/01 - Daily	GR - GRAB
					Permit Req.								<=	.1 INST MAX	19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1					19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.					>=	1 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	13.8		26 - lb/d			=	6.4	=	13	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV		26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L	1	01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

CBOD: The 2/8/12 sample was reported as LE (Lab error) due to the blank and GGA std outside QC limits. CBOD: The 2/15/12 sample result of 13.0 exceeds the 7-day avg permit limit of 11 mg/L. NH3-N: The 2/15/12 sample was reported as SE (Sampling error) due to a sample preservation error.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2012-03-14 16:01 (Time Zone: -05:00)