

Permit

Major: ☐

Facility:	ANDERSON MILL MUD WWTP
Facility Location:	1700' SW INTX USHWY 183 FM 620 WILLIAMSON COUNTY AUSTIN, TX 78750

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Status: NetDMR Validated

P = 2-HOUR PEAK.11459-001

Title:	Director	Telephone:	512-972-0101
---------------	----------	-------------------	--------------

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	Mgal/d								0	Continuous	TOTALZ	
					Value NODI															99/99 - Continuous	TM - TOTALZ
					Sample																
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample									=	0.03	19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.								<=	.1 INST MAX	19 - mg/L		01/01 - Daily		GR - GRAB		
					Value NODI																
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample						=	1.09				19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.								>=	1 MO MIN		19 - mg/L			01/01 - Daily	GR - GRAB	
					Value NODI																
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	10			26 - lb/d			=	5.2	=	9.2	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L			01/07 - Weekly	CP - COMPOS
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2012-02-15 09:08 (Time Zone: -06:00)