

DMR Copy of Record

Permit

Permit #:	TX0034207	Permittee:	AUSTIN,CITY OF	Facility:	ANDERSON MILL MUD WWTP
Major:	☒	Permittee Address:	1700' SW INTX USHWY 183/FM 620 AUSTIN, TX 78750	Facility Location:	1700' SW INTX USHWY 183 FM 620 WILLIAMSON COUNTY AUSTIN, TX 78750
Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY - 001		

Report Dates & Status

Monitoring Period:	From 06/01/12 to 06/30/12	DMR Due Date:	07/20/12	Status:	NetDMR Validated
--------------------	---------------------------	---------------	----------	---------	------------------

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name:	Greg	Title:	Director	Telephone:	512-972-0101
Last Name:	Meszaros				

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6					19 - mg/L	0	05/30 - 5 Times Every Month	GR - GRAB
					Permit Req.						>=	4 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.7			=	7	12 - SU	0	12/30 - Twelve Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	4.6			26 - lb/d			=	1.9	=	2.1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.4			26 - lb/d			=	0.2	=	0.2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV			26 - lb/d			<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.28	=	0.39	03 - MGD								99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	TM - TOTALZ	
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.08	19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.							<=	.1 INST MAX	19 - mg/L		01/01 - Daily		GR - GRAB		
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1				19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	1 MO MIN				19 - mg/L			01/01 - Daily	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	7.1			26 - lb/d		<	2.9	=	3.6	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L			01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2012-07-12 12:50 (Time Zone: -05:00)