

Permit

Major: 

Permittee:	AUSTIN,CITY OF
Permittee Address:	1700' SW INTX USHWY 183/FM 620 AUSTIN, TX 78750

Facility:	ANDERSON MILL MUD WWTP
Facility Location:	1700' SW INTX USHWY 183 FM 620 WILLIAMSON COUNTY AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Monitoring Period: From 05/01/12 to 05/31/12

DMR Due Date: 06/20/12

Status: NetDMR Validated

P = 2-HOUR PEAK.11459-001

First Name: Greg
Last Name: Meszaros

Title:	Director:
1. The Great Gatsby	Baz Luhrmann
2. The Catcher in the Rye	John Hughes
3. The Sound of Music	Robert Alton
4. The Godfather	Francis Ford Coppola
5. The Shawshank Redemption	Frank Darabont
6. The Godfather Part II	Francis Ford Coppola
7. The Godfather Part III	Francis Ford Coppola
8. The Godfather: The Collection	Francis Ford Coppola
9. The Godfather: The Godfather	Francis Ford Coppola
10. The Godfather: The Godfather	Francis Ford Coppola

Telephone: 512-972-0101

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--		<=	.99 DAILY AV		Req Mon DAILY MX	MGD							0	Continuous	TOTALZ
					Permit Req.													99/99 - Continuous	TM - TOTALZ
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.05	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.						<=	.1 INST MAX	19 - mg/L	01/01 - Daily	GR - GRAB				
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1				19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	1 MO MIN		19 - mg/L	01/01 - Daily	GR - GRAB				
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	13.1			26 - lb/d		=	4.8	=	6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: dana.white@austintexas.gov

Name: Dana White

E-Mail: dana.white@austintexas.gov

Date/Time:

2012-06-13 10:14 (Time Zone: -05:00)