

DMR Copy of Record

Permit

Permit #:TX0034207

Major:☒

Permittee:AUSTIN,CITY OF

Permittee Address:1700' SW INTX USHWY 183/FM 620
AUSTIN, TX 78750

Facility:ANDERSON MILL MUD WWTP

Facility Location:1700' SW INTX USHWY 183 FM 620
WILLIAMSON COUNTY
AUSTIN, TX 78750

Permitted Feature:001
External Outfall

Discharge:001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period:From 09/01/12 to 09/30/12

DMR Due Date:10/20/12

Status:NetDMR Validated

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name:Greg

Last Name:Meszaros

Title:Director

Telephone:512-972-0101

No Data Indicator (NODI)

Form NODI:--

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	5.7					19 - mg/L	0	09/30 - Nine Per Month	GR - GRAB
					Permit Req.						>=	4 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.3			=	6.9	12 - SU	0	12/30 - Twelve Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	6.6			26 - lb/d			=	2.6	=	6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.5			26 - lb/d			=	0.2	=	0.3	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV			26 - lb/d			<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.27	=	0.35	03 - MGD								99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	TM - TOTALZ	
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.09	19 - mg/L		01/01 - Daily	GR - GRAB		
					Permit Req.							<=	.1 INST MAX	19 - mg/L		0	01/01 - Daily	GR - GRAB		
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1				19 - mg/L		01/01 - Daily	GR - GRAB		
					Permit Req.					>=	1 MO MIN				19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	7.4			26 - lb/d		=	3	=	3.2	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: dana.white@austintexas.gov
Name: Dana White
E-Mail: dana.white@austintexas.gov

Date/Time: 2012-10-17 10:54 (Time Zone: -05:00)