

## DMR Copy of Record

### Permit

Permit #: TX0097870

Major:

Permitted Feature: 001  
External Outfall

### Report Dates & Status

Monitoring Period: From 11/01/12 to 11/30/12

### Considerations for Form Completion

WQ0012971-001

### Principal Executive Officer

First Name: Greg

Last Name: Meszaros

### No Data Indicator (NODI)

Form NODI: --

Permittee: AUSTIN, CITY OF  
Permittee Address: 1.4M N DESSAU RD&YAGER LANE  
AUSTIN, TX 78746

Discharge: 001-A  
DOMESTIC FACILITY - 001

Facility: DESSAU WWTF  
Facility Location: 1.4M N DESSAU RD AND YAGER LANE  
AUSTIN, TX 78746

DMR Due Date: 12/20/12

Status: NetDMR Validated

Title: Director

Telephone: 512-972-0101

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	7.9										19 - mg/L	17/30 - 17 Per Month	GR - GRAB
					Permit Req.	>=	5 MO MIN										19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.4						=	7.6		12 - SU	01/01 - Daily	GR - GRAB	
					Permit Req.	>=	6 MINIMUM					<=	9 MAXIMUM		12 - SU	02/30 - Twice Per Month	GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	5.6			26 - lb/d			=	4.2		19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	63 DAILY AV			26 - lb/d			<=	15 DAILY AV		19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.3			26 - lb/d			<	0.2		19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	13 DAILY AV			26 - lb/d			<=	3 DAILY AV		19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru	1 - Effluent	0	--	Sample	=	0.16	=	0.19	03 - MGD							99/99 - Continuous	TM - TOTALZ	
					Permit	<=	.5 DAILY		Req Mon	03 -								99/99 -	TM -

	treatment plant	Gross			Req.	AV	DAILY MX	MGD								Continuous	TOTALZ		
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample			=	1.14		=	3.5	19 - mg/L		0	01/01 - Daily	GR - GRAB		
					Permit Req.			>=	1 MO MIN		<=	4 MO MAX	19 - mg/L		0	01/01 - Daily	GR - GRAB		
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample			<	1		=	4	30 - MPN/100mL		0	01/07 - Weekly	GR - GRAB		
					Permit Req.			<=	120 DAILY AV		<=	374 DAILY MX	3Z - CFU/100mL		0	01/07 - Weekly	GR - GRAB		
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	2.7			26 - lb/d	<	2	=	2	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	42 DAILY AV			26 - lb/d	<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E. Coli: Units reported in MPN/100mL, not CFU/100mL.

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov

Date/Time:

2012-12-12 15:42 (Time Zone: -06:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov