

## DMR Copy of Record

### Permit

Permit #: **TX0101532**

Major:

Permitted Feature: 001  
External Outfall

Permittee: AUSTIN, CITY OF  
Permittee Address: 0.25MI W OF INTX GILES RD & AUSTIN, TX 78701

Facility: HARRIS BRANCH WWTP  
Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701

Discharge: **001-A**  
DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: **From 06/01/12 to 06/30/12**

DMR Due Date: **07/20/12**

Status: **NetDMR Validated**

### Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

### Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

### No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	6.1									19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	5 MO MIN									19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.1						=	7.2	12 - SU	0	10/30 - Ten Per Month	GR - GRAB	
					Permit Req.	>=	6 MINIMUM					<=	9 MAXIMUM	12 - SU	01/30 - Monthly		GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2.1			26 - lb/d		=	1	=	1.4	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.3			26 - lb/d		<	0.1	=	0.1	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d		<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample	=	1.3			26 - lb/d		=	0.6	=	1.06	19 - mg/L	0	05/30 - 5 Times Every Month	GR - GRAB
					Permit Req.	<=	3.3 DAILY			26 - lb/d		<=	1 DAILY	<=	6 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB

ID	Parameter	Monitoring Location	Field	Type	Units	Value	Operator	Date/Time	Frequency	Status	AV		Sample Type	Remarks					
											AV	AV							
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--		Value NODI													
						Sample	=	0.26	=	0.43	03 - MGD				0	01/01 - Daily	IN - INSTAN		
						Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - MGD					0	05/WK - Five Per Week	IN - INSTAN	
50060	Chlorine, total residual	1 - Effluent Gross	0	--		Value NODI													
						Sample					=	1.2		=	4	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
						Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
X 51040	E. coli	1 - Effluent Gross	0	--		Value NODI													
						Sample					<	1	<	1	30 - MPN/100mL	0	01/30 - Monthly	GR - GRAB	
						Permit Req.					<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL	0	01/30 - Monthly	GR - GRAB	
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--		Value NODI													
						Sample	<	4.7				<	2.1	=	2.3	19 - mg/L	0	01/07 - Weekly	GR - GRAB
						Permit Req.	<=	17 DAILY AV				<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E.coli: Units reported in MPN/100mLs and NOT CFU/100mLs.

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@ci.austin.tx.us  
 Name: Jane Burazer  
 E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2012-07-12 12:55 (Time Zone: -05:00)