

DMR Copy of Record

Permit

Permit #: **TX0071889**

Major: ☐

Permitted Feature: 001
External Outfall

Report Dates & Status

Monitoring Period: **From 07/01/12 to 07/31/12**

Considerations for Form Completion

Permittee: AUSTIN, CITY OF (S AUSTIN REG)

Permittee Address: 13009 FALWELL LANE
DEL VALLE, TX 78767

Discharge: **001-A**
DOMESTIC FACILITY - 001

Facility: SOUTH AUSTIN REGIONAL WWTF

Facility Location: 13009 FALWELL LANE
DEL VALLE, TX 78767

DMR Due Date: **08/20/12**

Status: **NetDMR Validated**

Principal Executive Officer

First Name: Greg

Last Name: Meszaros

Title: Director, Austin Water Utility

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.6			=	7.4	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	538			26 - lb/d			=	1.5	=	2.6	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	44.9			26 - lb/d			<	0.1	=	0.8	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	43.8	=	61.4	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value															

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (S AUSTIN REG)

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2012-08-14 11:30 (Time Zone: -05:00)