

DMR Copy of Record

Permit #:
Major:

TX0071889
█

Permittee:
Permittee Address:

AUSTIN, CITY OF (S AUSTIN REG)
13009 FALWELL LANE
DEL VALLE, TX 78767

Facility:
Facility Location:

SOUTH AUSTIN REGIONAL WWTF
13009 FALWELL LANE
DEL VALLE, TX 78767

Permitted Feature:

001
External Outfall

Discharge:

001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 06/01/12 to 06/30/12

DMR Due Date:

07/20/12

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title:

Director, Austin Water Utility

Telephone:

512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6.5					19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	7			=	7.3	12 - SU	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/01 - Daily	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	489			26 - lb/d			=	1.4	=	2.6	19 - mg/L	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	34.8			26 - lb/d			<	0.1	=	0.1	19 - mg/L	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	41.7	=	45.8	03 - MGD								99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD								99/99 - Continuous	TM - TOTALZ
					Value NODI														
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	45138	78 - gal/min								99/99 - Continuous	TM - TOTALZ
					Permit Req.			<=	150000 2HR PEAK	78 - gal/min								99/99 - Continuous	TM - TOTALZ
					Value NODI														
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	40.9			03 - MGD								99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	75 ANNL AVG			03 - MGD								99/99 - Continuous	TM - TOTALZ
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample									=	0		19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.									<	.1 INST MAX		19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample						=	1.1					19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.						>=	1 MO MIN					19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample								>	139	>	2420	30 - MPN/100mL	05/WK - Five Per Week	GR - GRAB
					Permit Req.									Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL	05/WK - Five Per Week	GR - GRAB

Parameter		Monitoring Location	Season #	Param. NOD1		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Value NOD1													0	01/01 - Daily	CP - COMPOS
					Sample	<	696			26 - lb/d			<	2	<	2	19 - mg/L			
					Permit Req.	<=	6255 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L			
					Value NOD1															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E. Coli: Units reported in MPN/100mL, not CFU/100mL. BOD, carbonaceous: Result was reported as Lab Error (LE) for 06/05/12. BOD, carbonaceous: Result was reported as Lab Error (LE) for 06/28/12.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (S AUSTIN REG)

User:

jane.burazer@ci.austin.tx.us

Name:

Jane Burazer

E-Mail:

jane.burazer@ci.austin.tx.us

Date/Time:

2012-07-12 13:05 (Time Zone: -05:00)