



50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	NODI													99/99 - Continuous	TM - TOTALZ						
					Sample	=	44444	78 - gal/min																	
					Permit Req.	<=	150000 2HR PEAK	78 - gal/min																	
					Value NODI																				
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	42.3												99/99 - Continuous	TM - TOTALZ					
					Permit Req.	<=	75 ANNL AVG																		
					Value NODI																				
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0	19 - mg/L					01/01 - Daily	GR - GRAB					
					Permit Req.	<										<	.1 INST MAX	19 - mg/L				01/01 - Daily	GR - GRAB		
					Value NODI																				
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample				=	1				19 - mg/L					01/01 - Daily	GR - GRAB					
					Permit Req.	>=																	01/01 - Daily	GR - GRAB	
					Value NODI																				
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							>	100	>	2420	30 - MPN/100mL				05/WK - Five Per Week	GR - GRAB				
					Permit Req.																			05/WK - Five Per Week	GR - GRAB
					Value NODI																				
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	708					<	2	<	2	19 - mg/L				01/01 - Daily	CP - COMPOS				
					Permit Req.	<=	6255 DAILY AV	26 - lb/d								<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L				01/01 - Daily	CP - COMPOS
					Value NODI																				

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E. Coli: Units reported in MPN/100mL, not CFU/100mL. E. Coli: Frequency = 6/WK for the week of 23-29SEP12.

**Attachments**

No attachments.

*Report Last Saved By*

*AUSTIN, CITY OF (S AUSTIN REG)*

User: dana.white@austintexas.gov

Name: Dana White

E-Mail: dana.white@austintexas.gov

Date/Time:

2012-10-17 11:35 (Time Zone: -05:00)