

Permit

Major:

Permittee Address:	8250 CITATION AVE,2400F E. FMR AUSTIN, TX 787670000
---------------------------	--

Facility Location: 8250 CITATION AVE,2400F E. FMR 973
AUSTIN, TX 787670000

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Monitoring Period: From 06/01/12 to 06/30/12

DMR Due Date: 07/20/12

Status: NetDMR Validated

Principal Executive Officer

First Name: Greg

Title:	Director
--------	----------

Telephone: 512-972-0101

Last Name: Meszaros

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.024	=	0.032	MGD								Five Per Week	INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD							0	05/WK - Five Per Week	IN - INSTAN
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1			=	2.2	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2012-07-12 12:58 (Time Zone: -05:00)