

DMR Copy of Record

Permit

Permit #:	TX0046981	Permittee:	AUSTIN, CITY OF (WALNUT CREEK)	Facility:	CITY OF AUSTIN(WALNUT CREEK)
Major:	☒	Permittee Address:	7113 EAST FM 969 AUSTIN, TX 787678859	Facility Location:	7113 EAST FM 969 TRAVIS COUNTY AUSTIN, TX 787678859
Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY-OUTFALL 001		

Report Dates & Status

Monitoring Period:	From 11/01/12 to 11/30/12	DMR Due Date:	12/20/12	Status:	NetDMR Validated
--------------------	---------------------------	---------------	----------	---------	------------------

Considerations for Form Completion

Principal Executive Officer

First Name:	Greg	Title:	Director	Telephone:	512-972-0101
Last Name:	Meszaros				

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	7.3					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.7			=	7.3	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1026			26 - lb/d			=	2.5	=	12	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	151			26 - lb/d			<	0.4	=	2.1	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment	1 - Effluent Gross	0	--	Sample	=	50	=	55.2	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY		Req Mon DAILY	03 - MGD									99/99 - Continuous	TM - TOTALZ

	plant					AV		MX											
					Value NOD I														
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample		=	45854	78 - gal/min								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		<=	114583 2HR PEAK	78 - gal/min									99/99 - Continuous	TM - TOTALZ
					Value NOD I														
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	54		03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	75 ANNL AVG		03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NOD I														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0.05	19 - mg/L			0	01/01 - Daily	GR - GRAB
					Permit Req.							<	.1 INST MAX	19 - mg/L				01/01 - Daily	GR - GRAB
					Value NOD I														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample				=	1.1				19 - mg/L			0	01/01 - Daily	GR - GRAB
					Permit Req.				>=	1 MINIMUM				19 - mg/L				01/01 - Daily	GR - GRAB
					Value NOD I														
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	29	=	308	3Z - CFU/100mL		0	05/WK - Five Per Week	GR - GRAB
					Permit Req.							Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL			05/WK - Five Per Week	GR - GRAB
					Value NOD I														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	869		26 - lb/d		<	2.1	=	3.7	19 - mg/L			01/01 - Daily	CP - COMPOS
					Permit Req.	<=	6255 DAILY AV		26 - lb/d		<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		0	01/01 - Daily	CP - COMPOS
					Value NOD I														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

E.coli: Units reported in MPN/100 mLs and NOT CFU/100 mLs. CBOD: The 11/9/12 and 11/22/12 to 11/24/12 samples were reported as Lab Errors due to the GGA standard results outside of acceptable QC limits.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov
Name: Jane Burazer
E-Mail: jane.burazer@austintexas.gov

Date/Time: 2013-02-06 19:14 (Time Zone: -06:00)