

DMR Copy of Record

Permit

Permit #: **TX0046981**

Major: ☒

Permittee: AUSTIN, CITY OF (WALNUT CREEK)

Permittee Address: 7113 EAST FM 969
AUSTIN, TX 787678859

Facility: CITY OF AUSTIN(WALNUT CREEK)

Facility Location: 7113 EAST FM 969
TRAVIS COUNTY
AUSTIN, TX 787678859

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period: **From 09/01/12 to 09/30/12**

DMR Due Date: **10/20/12**

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NOD I		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	6.8					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NOD I															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.2			=	7.1	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NOD I															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	595			26 - lb/d			=	1.3	=	2.8	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NOD I															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	89			26 - lb/d			<	0.2	=	0.8	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NOD I															
50050	Flow, in conduit or thru treatment	1 - Effluent Gross	0	--	Sample	=	53.1	=	73.1	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY		Req Mon DAILY	03 - MGD									99/99 - Continuous	TM - TOTALZ

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov
Name: Jane Burazer
E-Mail: jane.burazer@austintexas.gov

Date/Time: 2013-02-06 19:09 (Time Zone: -06:00)