

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	01 SET	1 2 0 3 YEAR MO.	19743 EID
------------	--------------------------------	-----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE	UNITS					
000085342 TRANSFER DAYS/MON	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED				11	2/WEEK	03	GRABPKLOAD
316164024 FEC. COLI DLY AVG	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	0	MGD	0	NA	NA	NA	NA
	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	0	MG/L	0	NA	NA	NA	NA
	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	0	NTU	0	NA	NA	NA	NA
	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		NA	
	PERMITTED				01	01		NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	DATE	0	01		NA	
	PERMITTED				01	01		NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		NA	
	PERMITTED				01	01		NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson		1 2 0 4 0 9 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 2 0 4 0 9 YEAR MO. DAY
AREA CODE	NUMBER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	01 SET	1 2 0 3 YEAR MO.	19742 EID
------------	--------------------------------	-----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **OTFL 900 RECALIMED WATER TYPE II**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	VALUE	UNITS			01	03
000085342 TRANSFER DAYS/MON	REPORTED	31	DAY	0	01		01
	PERMITTED				01	NA	01 NA
316164024 FEC. COLI DLY AVG	REPORTED	<4	#/100 ML	0	11	2/WEEK	03 GRABPKLOAD
	PERMITTED	200.000			14	1/WEEK	03 GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	56	#/100 ML	0	11	2/WEEK	03 GRABPKLOAD
	PERMITTED	800.000			14	1/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	2.77	MGD	0	02	CONT	11 CONT
	PERMITTED				14	1/WEEK	12 INSTANT
800821024 BOD CARB DLY AVG	REPORTED	<2.0	MG/L	0	11	2/WEEK	03 GRABPKLOAD
	PERMITTED	15.000			14	1/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		NA
	PERMITTED				01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	DATE	0	01		NA
	PERMITTED				01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		NA
	PERMITTED				01	01	NA NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889. South Austin Regional WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1 2 0 4 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1 2 0 4 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	01 SET	1 2 0 3 YEAR MO.	19744 EID
------------	--------------------------------	-----------	---------------------------	--------------

THIS REPORT TO BE USED FOR **COMBINED OTFL 001 AND RECLAIMED WATER**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS			
500507124 FLOW	REPORTED	0	0	01		01	
DAILY AVG	PERMITTED						
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	0	01		NA	NA
	PERMITTED						
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	0	01		NA	NA
	PERMITTED						
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	0	01		NA	NA
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1 2 0 4 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1 2 0 4 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865**



40B SYS	WQ0010543-011 PERMIT NUMBER	01 SET	1 2 0 3 YEAR MO.	15650 EID
------------	--------------------------------	-----------	---------------------------	--------------

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	VALUE		UNITS				
316164024 FEC. COLI DLY AVG	REPORTED	<2	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	20.000						
316164030 FEC. COLI IND GRAB	REPORTED	<2	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	75.000						
500507124 FLOW DLY AVG	REPORTED	0.04	MGD	0	02	CONT	11	CONT
	PERMITTED							
800821024 BOD CARB DLY AVG	REPORTED	<2.0	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	5.000						
820796624 TURBIDITY 30DAYAVG	REPORTED	2.49	NTU	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	3.000						
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA	NA
	PERMITTED							
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01		NA	NA
	PERMITTED							
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA	NA
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)
 Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.
 Walnut Creek WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 2 0 4 0 9 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 2 0 4 0 9 YEAR MO. DAY
AREA CODE NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	01	1 2	0 3	15651
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **OTFL 900 RECLAIMED WATER TYPE II**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE	UNITS					
000085342 TRANSFER DAYS MON	REPORTED	0	DAY	0	01		01	
	PERMITTED							
316164024 FEC. COLI DLY AVG	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	200.000						
316164030 FEC. COLI IND GRAB	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	800.000						
500507124 FLOW DLY AVG	REPORTED	0	MGD	0	NA	NA	NA	NA
	PERMITTED							
800821024 BOD CARB DLY AVG	REPORTED	0	MG/L	0	NA	NA	NA	NA
	PERMITTED	15.000						
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA	
	PERMITTED							
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/11/12	DATE	0	01		NA	
	PERMITTED							
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA	
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	Mike Welch		1 2 0 4 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 2 0 4 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865**

Page 3 of 3



40B	WQ0010543-011	01	1 2	0 3	15652
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OUTFALLS 001 AND RECLAIMED WATER**
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
500507124 FLOW	REPORTED		0	MGD	0	01	01	
DAILY AVG	PERMITTED				01	NA	01	NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED		0	NUMBER	01		NA	
	PERMITTED				01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		0	DATE	01		NA	
	PERMITTED				01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		0	LETTER	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 2 0 4 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 2 0 4 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY