

Permit

Major:

Permittee:	AUSTIN,CITY OF
Permittee Address:	1700' SW INTX USHWY 183/FM 620 AUSTIN, TX 78750

Facility:	ANDERSON MILL MUD WWTP
Facility Location:	1700' SW INTX USHWY 183 FM 620 WILLIAMSON COUNTY AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Monitoring Period: From 04/01/13 to 04/30/13

DMR Due Date: 05/20/13

Status: NetDMR Validated

P = 2-HOUR PEAK.11459-001

First Name: Greg

Last Name: Meszaros

Title:	Director:
--------	-----------

Telephone: 512-972-0101

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.33	=	0.44	03 - MGD								99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	TM - TOTALZ	
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.1	19 - mg/L		01/01 - Daily	GR - GRAB		
					Permit Req.							<=	.1 INST MAX	19 - mg/L		0	01/01 - Daily	GR - GRAB		
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1				19 - mg/L		01/01 - Daily	GR - GRAB		
					Permit Req.					>=	1 MO MIN				19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	9.1			26 - lb/d		=	3.2	=	4.2	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

On April 16th, the effluent had a chlorine residual of 0.10 mg/L. The permit states that the residual must be less than 0.10 mg/L.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov
Name: Jane Burazer
E-Mail: jane.burazer@austintexas.gov

Date/Time: 2013-05-13 17:43 (Time Zone: -05:00)