

DMR Copy of Record

Permit

Permit #: **TX0034207**
 Major:

Permittee: AUSTIN,CITY OF
 Permittee Address: 1700' SW INTX USHWY 183/FM 620
 AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP
 Facility Location: 1700' SW INTX USHWY 183 FM 620
 WILLIAMSON COUNTY
 AUSTIN, TX 78750

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 02/01/13 to 02/28/13

DMR Due Date: 03/20/13

Status: **NetDMR Validated**

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	6.2				19 - mg/L	0	24/30 - 24 Per Month	GR - GRAB	
					Permit Req.					>=	4 MO MIN				19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.5		=	7.3	12 - SU	0	26/30 - 26 Per Month	GR - GRAB	
					Permit Req.					>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	12.9				26 - lb/d	=	5.3	=	6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV			26 - lb/d	<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	1				26 - lb/d	=	0.4	=	0.8	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV			26 - lb/d	<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS	
					Value NODI														
					Sample	=	0.32	=	0.47		03 -						99/99 -	TM -	

										MGD											Continuous	TOTALZ	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV	Req Mon DAILY MX	03 - MGD									0	99/99 - Continuous	TM - TOTALZ			
					Value NODI																		
					Sample																		
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Permit Req.								=	0.05	19 - mg/L		0	01/01 - Daily	GR - GRAB				
					Value NODI																		
					Sample																		
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Permit Req.													0	01/01 - Daily	GR - GRAB			
					Value NODI																		
					Sample							=	1					19 - mg/L		01/01 - Daily	GR - GRAB		
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Permit Req.	<=	58 DAILY AV		26 - lb/d				<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS			
					Value NODI																		
					Sample	=	10.1		26 - lb/d			=	4.1	=	5.6	19 - mg/L		01/07 - Weekly	CP - COMPOS				

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-03-14 09:57 (Time Zone: -05:00)