

# DMR Copy of Record

**Permit**

Permit #: **TX0034207**  
 Major:

Permittee: AUSTIN,CITY OF  
 Permittee Address: 1700' SW INTX USHWY 183/FM 620  
 AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP  
 Facility Location: 1700' SW INTX USHWY 183 FM 620  
 WILLIAMSON COUNTY  
 AUSTIN, TX 78750

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY - 001

**Report Dates & Status**

Monitoring Period: **From 01/01/13 to 01/31/13**

DMR Due Date: **02/20/13**

Status: **NetDMR Validated**

**Considerations for Form Completion**

P = 2-HOUR PEAK.11459-001

**Principal Executive Officer**

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

**No Data Indicator (NODI)**

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	5.9					19 - mg/L	0	25/30 - 25 Per Month	GR - GRAB
					Permit Req.					>=	4 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.8		=	7.4	12 - SU	0	28/30 - 28 Per Month	GR - GRAB	
					Permit Req.					>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	21.9				26 - lb/d	=	7.4	=	11.9	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV			26 - lb/d	<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.6				26 - lb/d	=	0.2	=	0.3	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV			26 - lb/d	<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS	
					Value NODI														
					Sample	=	0.32	=	0.42	03 -							99/99 -	TM -	

										MGD					Continuous	TOTALZ					
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV	Req Mon DAILY MX	03 - MGD						0	99/99 - Continuous	TM - TOTALZ				
					Value NODI																
					Sample																
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Permit Req.							=	0.06	19 - mg/L	0	01/01 - Daily	GR - GRAB				
					Value NODI																
					Sample						=	1				19 - mg/L	0	01/01 - Daily	GR - GRAB		
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Permit Req.							>=	1 MO MIN	19 - mg/L	0	01/01 - Daily	GR - GRAB				
					Value NODI																
					Sample	=	10.7						=	3.7	=	4.8	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Permit Req.	<=	58 DAILY AV		26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Value NODI																
					Sample																

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

1/1/13 to 1/2/13: The plant was offline and not discharging.

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-02-13 17:30 (Time Zone: -06:00)