

## DMR Copy of Record

### Permit

Permit #: **TX0034207**  
 Major:

Permittee: AUSTIN,CITY OF  
 Permittee Address: 1700' SW INTX USHWY 183/FM 620  
 AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP  
 Facility Location: 1700' SW INTX USHWY 183 FM 620  
 WILLIAMSON COUNTY  
 AUSTIN, TX 78750

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: **From 05/01/13 to 05/31/13**

DMR Due Date: **06/20/13**

Status: **NetDMR Validated**

### Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

### Principal Executive Officer

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

### No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	7.1					19 - mg/L	0	27/30 - 27 Per Month	GR - GRAB	
					Permit Req.						>=	4 MO MIN							19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.6		=	7.4	12 - SU	0	01/01 - Daily	GR - GRAB		
					Permit Req.						>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB		
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	11.3			26 - lb/d		=	4	=	5.8	19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	124 DAILY AV			26 - lb/d		<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS		
					Value NODI																
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.8			26 - lb/d		=	0.3	=	0.8	19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	25 DAILY AV			26 - lb/d		<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS		
					Value NODI																
					Sample	=	0.34	=	0.42	03 - MGD							99/99 - Continuous	TM - TOTALZ			

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV	Req Mon DAILY MX	03 - MGD								0	99/99 - Continuous	TM - TOTALZ		
					Value NODI																
X 50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0.12	19 - mg/L				01/01 - Daily	GR - GRAB		
					Permit Req.						<=	.1 INST MAX	19 - mg/L						1	01/01 - Daily	GR - GRAB
					Value NODI																
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1.1			19 - mg/L				01/01 - Daily	GR - GRAB		
					Permit Req.						>=	1 MO MIN							0	01/01 - Daily	GR - GRAB
					Value NODI																
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	7.8		26 - lb/d		<	2.8	=	4.4	19 - mg/L			01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	58 DAILY AV		26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L				0	01/07 - Weekly	CP - COMPOS
					Value NODI																

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
50060	Chlorine, total residual	A - Disinfection, Process Complete	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	<input checked="" type="checkbox"/>

**Comments**

Excursion: 5/5/13 the result was 0.12mg/L which exceeds the permit limit of less than 0.1 mg/L.

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov  
 Name: Jane Burazer  
 E-Mail: jane.burazer@austintexas.gov

Date/Time: 2013-06-11 16:54 (Time Zone: -05:00)