

DMR Copy of Record

Permit

Permit #: TX0034207	Permittee: AUSTIN,CITY OF	Facility: ANDERSON MILL MUD WWTP
Major:	Permittee Address: 1700' SW INTX USHWY 183/FM 620 AUSTIN, TX 78750	Facility Location: 10502 MELLOW MEADOW PKWY WILLIAMSON COUNTY AUSTIN, TX 78750
Permitted Feature: 001 External Outfall	Discharge: 001 - A DOMESTIC FACILITY - 001	

Report Dates & Status

Monitoring Period: From 11/01/13 to 11/30/13	DMR Due Date: 12/20/13	Status: NetDMR Validated
---	-------------------------------	---------------------------------

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg	Title: Director	Telephone: 512-972-0101
Last Name: Meszaros		

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	6.5					19 - mg/L	0	10/30 - Ten Per Month	GR - GRAB
					Permit Req.						>=	4 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6		=	7.4	12 - SU	0	14/30 - 14 Per Month	GR - GRAB	
					Permit Req.						>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	8			26 - lb/d			=	3.2	=	4.8	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.7			26 - lb/d			=	0.3	=	0.4	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV			26 - lb/d			<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
					Sample	=	0.27	=	0.75	03 - MGD								99/99 - Continuous	TM - TOTALZ	

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV	Req Mon DAILY MX	03 - MGD						0	99/99 - Continuous	TM - TOTALZ
					Value NODI												
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample						=	0.07	19 - mg/L		0	01/01 - Daily	GR - GRAB
					Permit Req.	<=	.1 INST MAX									01/01 - Daily	GR - GRAB
					Value NODI												
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1		19 - mg/L		0	01/01 - Daily	GR - GRAB
					Permit Req.	>=	1 MO MIN						19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI												
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	7.8		26 - lb/d		<	2.6	=	4	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV		26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI												

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Date/Time: 2013-12-13 09:59 (Time Zone: -06:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov