

DMR Copy of Record

Permit

Permit #: **TX0034207**

Major: ☒

Permittee: AUSTIN,CITY OF

Permittee Address: 1700' SW INTX USHWY 183/FM 620
AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP

Facility Location: 1700' SW INTX USHWY 183 FM 620
WILLIAMSON COUNTY
AUSTIN, TX 78750

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 09/01/13 to 09/30/13**

DMR Due Date: **10/20/13**

Status: **NetDMR Validated**

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	6.4					19 - mg/L	0	10/30 - Ten Per Month	GR - GRAB
					Permit Req.						> =	4 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.3			=	7.5	12 - SU	0	20/30 - Twenty Per Month	GR - GRAB
					Permit Req.						> =	6 MINIMUM			< =	9 MAXIMUM	12 - SU		02/DM - Twice Every Month	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3.7			26 - lb/d			=	1.4	=	2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	< =	124 DAILY AV			26 - lb/d			< =	15 DAILY AV	< =	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.4			26 - lb/d			=	0.2	=	0.3	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	< =	25 DAILY AV			26 - lb/d			< =	3 DAILY AV	< =	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Value NODI													0		
					Sample	=	0.34	=	0.44	03 - MGD									28/30 - 28 Per Month	TM - TOTALZ
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample										=	0.05	19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.										<=	.1 INST MAX	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample						=	1					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	1 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	6			26 - lb/d			<	2.1	=	2.4	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN,CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-10-13 13:51 (Time Zone: -05:00)