

50050	conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	DAILY AV	Mon DAILY MX	03 - MGD							0	99/99 - Continuous	TM - TOTALZ	
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.02		=	3.8	19 - mg/L		01/01 - Daily	GR - GRAB	
					Permit Req.				>=	1 MO MIN		<=	4 MO MAX	19 - mg/L		01/01 - Daily	GR - GRAB		
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample					<	1		=	2	30 - MPN/100mL		01/07 - Weekly	GR - GRAB	
					Permit Req.				<=	120 DAILY AV		<=	374 DAILY MX	3Z - CFU/100mL		01/07 - Weekly	GR - GRAB		
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	2.7		26 - lb/d		<	2.1		=	2.5	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	42 DAILY AV		26 - lb/d		<=	10 DAILY AV		<=	25 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E.Coli: Units reported in MPN/100mL, NOT CFU/100mL.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov
 Name: Jane Burazer
 E-Mail: jane.burazer@austintexas.gov

Date/Time: 2013-05-13 17:41 (Time Zone: -05:00)