

## DMR Copy of Record

### Permit

Permit #: **TX0101532**  
 Major:

Permittee: AUSTIN, CITY OF  
 Permittee Address: 0.25MI W OF INTX GILES RD & AUSTIN, TX 78701

Facility: HARRIS BRANCH WWTP  
 Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: From 04/01/13 to 04/30/13

DMR Due Date: 05/20/13

Status: **NetDMR Validated**

### Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

### Principal Executive Officer

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

### No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	6.5								19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	5 MO MIN								19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.2					=	7.7	12 - SU	0	14/30 - 14 Per Month	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM	12 - SU	01/30 - Monthly		GR - GRAB		
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2.5			26 - lb/d	=	1.4	=	2.4	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d	<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI													
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	1.7			26 - lb/d	=	0.8	=	2.6	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d	<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI													
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample	=	0.43			26 - lb/d	=	0.24	=	0.4	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	3.3 DAILY			26 - lb/d	<=	1 DAILY	<=	6 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB

					AV				AV									
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.22	=	0.32	03 - MGD			0	01/01 - Daily	IN - INSTAN			
					Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - MGD				05/WK - Five Per Week	IN - INSTAN			
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample				=	1.1		=	2.6	19 - mg/L	05/WK - Five Per Week	GR - GRAB		
					Permit Req.				>=	1 MO MIN		<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB		
					Value NODI													
51040	E. coli	1 - Effluent Gross	0	--	Sample											0	01/30 - Monthly	GR - GRAB
					Permit Req.					<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL				
					Value NODI													
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	4.4			26 - lb/d		<	2.5	=	3.5	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

Ecoli excursion, no sample collected, permit frequency is 1 grab/ month.

**Attachments**

No attachments.

**Report Last Saved By**

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-05-13 17:49 (Time Zone: -05:00)