

DMR Copy of Record

Permit

Permit #: **TX0101532**
 Major:

Permittee: AUSTIN, CITY OF
 Permittee Address: 0.25MI W OF INTX GILES RD & AUSTIN, TX 78701

Facility: HARRIS BRANCH WWTP
 Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 09/01/13 to 09/30/13**

DMR Due Date: **10/20/13**

Status: **NetDMR Validated**

Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7.2								19 - mg/L	0	06/30 - Six Per Month	GR - GRAB
					Permit Req.	>=	5 MO MIN								19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.3					=	7.7	12 - SU	0	26/30 - 26 Per Month	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM	12 - SU	01/30 - Monthly		GR - GRAB		
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.4		26 - lb/d		=	0.8	=	1	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV		26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI													
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	1.4		26 - lb/d		=	0.8	=	0.9	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	6.7 DAILY AV		26 - lb/d		<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI													
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	<	0.3		26 - lb/d		<	0.2	=	0.38	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	3.3 DAILY AV		26 - lb/d		<=	1 DAILY AV	<=	6 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.25	=	0.52	03 - MGD							0	01/01 - Daily	IN - INSTAN	
					Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - MGD								05/WK - Five Per Week	IN - INSTAN	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.1		=	3.9	19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L			05/WK - Five Per Week	GR - GRAB	
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample						=	20	=	20	30 - MPN/100mL		0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL			01/30 - Monthly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	5			26 - lb/d		=	2.6	=	3.2	19 - mg/L		0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L			01/07 - Weekly	GR - GRAB
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E.Coli: units reported in MPN/100mL, not CFU/100mL. The 2 hour peak flow limit of 833 GPM was exceeded on 9/28/13 with a flow of 905 GPM.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Date/Time:

2013-10-13 13:56 (Time Zone: -05:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov