

50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	NODI													99/99 - Continuous	TM - TOTALZ					
					Sample	=	46527	78 - gal/min																
					Permit Req.	<=	150000 2HR PEAK	78 - gal/min																
					Value NODI																			
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	40.6												99/99 - Continuous	TM - TOTALZ				
					Permit Req.	<=	75 ANNL AVG																	
					Value NODI																			
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0						01/01 - Daily	GR - GRAB				
					Permit Req.											<	.1 INST MAX					01/01 - Daily	GR - GRAB	
					Value NODI																			
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample				=	1									01/01 - Daily	GR - GRAB				
					Permit Req.																			
					Value NODI																			
X 51040	E. coli	1 - Effluent Gross	0	--	Sample															05/WK - Five Per Week	GR - GRAB			
					Permit Req.																			
					Value NODI																			
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	716													01/01 - Daily	CP - COMPOS			
					Permit Req.	<=	6255 DAILY AV																	
					Value NODI																			

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E. Coli: Units reported in MPN/100mL, not CFU/100mL. pH: Result was reported as Lab Error (LE) for 04/21/13

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (S AUSTIN REG)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-05-13 18:08 (Time Zone: -05:00)