

DMR Copy of Record

Permit

Permit #: **TX0071889**
 Major:

Permittee: AUSTIN, CITY OF (S AUSTIN REG)
 Permittee Address: 13009 FALWELL LANE
 DEL VALLE, TX 78767

Facility: SOUTH AUSTIN REGIONAL WWTF
 Facility Location: 13009 FALWELL LANE
 DEL VALLE, TX 78767

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 07/01/13 to 07/31/13

DMR Due Date: 08/20/13

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director, Austin Water Utility

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	6.5									19 - mg/L	01/01 - Daily	GR - GRAB	
					Permit Req.	>=	6 MO MIN										19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.9					=	7.2		12 - SU	01/01 - Daily	GR - GRAB		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM		12 - SU	01/01 - Daily	GR - GRAB			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	442		26 - lb/d		=	1.3		=	2	19 - mg/L	01/01 - Daily	CP - COMPOS	
					Permit Req.	<=	9383 DAILY AV		26 - lb/d		<=	15 DAILY AV		<=	40 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	40.5		26 - lb/d		<	0.1		=	0.2	19 - mg/L	01/01 - Daily	CP - COMPOS	
					Permit Req.	<=	1251 DAILY AV		26 - lb/d		<=	2 DAILY AV		<=	10 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	41.4	=	50.2	03 - MGD							99/99 - Continuous	TM - TOTALZ	
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units					
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Value NODI												0	99/99 - Continuous	TM - TOTALZ		
					Sample		=	48263	78 - gal/min												
					Permit Req.		<=	150000 2HR PEAK	78 - gal/min												
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Value NODI												0	99/99 - Continuous	TM - TOTALZ		
					Sample	=	40.5		03 - MGD												
					Permit Req.	<=	75 ANNL AVG		03 - MGD												
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Value NODI												0	01/01 - Daily	GR - GRAB		
					Sample					=	0	19 - mg/L									
					Permit Req.					<	.1 INST MAX	19 - mg/L									
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Value NODI												0	01/01 - Daily	GR - GRAB		
					Sample					=	1	19 - mg/L									
					Permit Req.					>=	1 MO MIN	19 - mg/L									
X 51040	E. coli	1 - Effluent Gross	0	--	Value NODI												0	05/WK - Five Per Week	GR - GRAB		
					Sample					=	52	=	816	30 - MPN/100mL							
					Permit Req.						Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL							
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Value NODI												0	01/01 - Daily	CP - COMPOS		
					Sample	<	702		26 - lb/d		<	2	=	3.4	19 - mg/L						
					Permit Req.	<=	6255 DAILY AV		26 - lb/d		<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L						
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E. Coli: Units reported as MPN/100mL, not CFU/100mL. BOD, carbonaceous: Result was reported as Lab Error (LE) for 07/18/13. From 7-2-13 to 7-31-13, the BOD chart recorder temperature does not match the NBS traceable thermometer due to mechanical error.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (S AUSTIN REG)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-08-14 13:51 (Time Zone: -05:00)