

50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	NODI													99/99 - Continuous	TM - TOTALZ			
					Sample	=	45486	78 - gal/min														
					Permit Req.	<=	150000 2HR PEAK	78 - gal/min														
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	40.5	03 - MGD											99/99 - Continuous	TM - TOTALZ		
					Permit Req.	<=	75 ANNL AVG	03 - MGD														
					Value NODI																	
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample						=	0	19 - mg/L						01/01 - Daily	GR - GRAB		
					Permit Req.						<	.1 INST MAX	19 - mg/L									
					Value NODI																	
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample				=	1			19 - mg/L						01/01 - Daily	GR - GRAB		
					Permit Req.						>=	1 MO MIN										
					Value NODI																	
X 51040	E. coli	1 - Effluent Gross	0	--	Sample						=	18	=	435	30 - MPN/100mL					05/WK - Five Per Week	GR - GRAB	
					Permit Req.									Req Mon DAILY AV			Req Mon DAILY MX	3Z - CFU/100mL				
					Value NODI																	
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	766	26 - lb/d			<	2.1	=	4.5	19 - mg/L					01/01 - Daily	CP - COMPOS	
					Permit Req.	<=	6255 DAILY AV	26 - lb/d					<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L					
					Value NODI																	

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E.Coli: Units reported as MPN/100mL, not CFU/100mL. Nitrogen, ammonia total (as N): Result was reported as Lab Error (LE) for 05/20/13

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (S AUSTIN REG)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-06-11 17:15 (Time Zone: -05:00)