

DMR Copy of Record

Permit

Permit #:

TX0067466

Major:

Permittee:

AUSTIN, CITY OF

Permittee Address:

8250 CITATION AVE,2400F E. FMR
AUSTIN, TX 787670000

Facility:

THOROUGHbred FARMS WWTP

Facility Location:

8250 CITATION AVE,2400F E. FMR 973
AUSTIN, TX 787670000

Permitted Feature:

001
External Outfall

Discharge:

001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period:

From 12/01/13 to 12/31/13

DMR Due Date:

01/20/14

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

Greg

Last Name:

Meszaros

Title:

Director

Telephone:

512-972-0101

No Data Indicator (NODI)

Form NODI:

--

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.4					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	2 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.4			26 - lb/d			<	2	<	2	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7			=	7.7	12 - SU	0	22/30 - 22 Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.4			26 - lb/d			=	1.7	=	2	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
	Flow, in conduit or	1 - Effluent			Sample	=	0.029	=	0.039	03 - MGD									01/01 - Daily	IN - INSTAN
					Permit		.065		Req Mon	03 -									05/WK -	IN -

file:///C:/Users/CourtrightK/Documents/netdmr_cor_zips_2014_03_13_12_55_37/TX0067466-001-A_mped2013_12_31_subd2014_01_14_n3/dmrSubmission.xml[3/13/2014 12:58:02 PM]

50050	thru treatment plant	Gross	0	--	Req.	<=	DAILY AV		DAILY MX	MGD								0	Five Per Week	INSTAN
					Value NODI															
					Sample						=	1			=	3.9	19 - mg/L		22/30 - 22 Per Month	GR - GRAB
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

CBOD from 12/4/13 was given a result of LE (Laboratory Error) due to the samples going out of the acceptable temperature range.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User:	dana.white@austintexas.gov	Date/Time:	2014-01-14 15:40 (Time Zone: -06:00)
Name:	Dana White		
E-Mail:	dana.white@austintexas.gov		