

DMR Copy of Record

Permit

Permit #:
Major:

TX0067466

Permittee:
Permittee Address:

AUSTIN, CITY OF
8250 CITATION AVE,2400F E. FMR
AUSTIN, TX 787670000

Facility:
Facility Location:

THOROUGHbred FARMS WWTP
8250 CITATION AVE,2400F E. FMR 973
AUSTIN, TX 787670000

Permitted Feature:

001
External Outfall

Discharge:

001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period:

From 07/01/13 to 07/31/13

DMR Due Date:

08/20/13

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:
Last Name:

Greg
Meszaros

Title:

Director

Telephone:

512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	5.2					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	2 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.7			26 - lb/d			<	2.5	=	3.2	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.5			=	8.4	12 - SU	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.7			26 - lb/d			=	2.7	=	3	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.033	=	0.04	03 - MGD								0	29/30 - 29 Per Month	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD									05/WK - Five Per Week	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1.12			=	3.8	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-08-14 13:37 (Time Zone: -05:00)