

DMR Copy of Record

Permit

Permit #:

TX0046981

Major:

Permittee:

AUSTIN, CITY OF (WALNUT CREEK)

Permittee Address:

7113 EAST FM 969
AUSTIN, TX 787678859

Facility:

CITY OF AUSTIN(WALNUT CREEK)

Facility Location:

7113 EAST FM 969
TRAVIS COUNTY
AUSTIN, TX 787678859

Permitted Feature:

001
External Outfall

Discharge:

001-A
DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period:

From 12/01/13 to 12/31/13

DMR Due Date:

01/20/14

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

Greg

Last Name:

Meszaros

Title:

Director

Telephone:

512-972-0101

No Data Indicator (NODI)

Form NODI:

--

50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample		=	52767	78 - gal/min									99/99 - Continuous	TM - TOTALZ
					Permit Req.		<=	114583 2HR PEAK	78 - gal/min									99/99 - Continuous	TM - TOTALZ
					Value NODI														
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=		52.6	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=		75 ANNL AVG	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0	19 - mg/L			01/01 - Daily	GR - GRAB
					Permit Req.								<	.1 INST MAX	19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample				=	1.1					19 - mg/L			01/01 - Daily	GR - GRAB
					Permit Req.				>=	1 MINIMUM					19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	3	=	23	30 - MPN/100mL		22/30 - 22 Per Month	GR - GRAB
					Permit Req.								Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL		05/WK - Five Per Week	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<		842	26 - lb/d			<	2	=	2.1	19 - mg/L		01/01 - Daily	CP - COMPOS
					Permit Req.	<=		6255 DAILY AV	26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	

Comments

CBODs from 12/1/13 to 12/4/13 were given a result of LE (Laboratory Error) due to the samples going out of the acceptable temperature range. E.Coli: Units reported in MPN / 100 mL, not CFU / 100 mL.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

Name:	Dana White
E-Mail:	dana.white@austintexas.gov