

DMR Copy of Record

Permit

Permit #: **TX0046981**
 Major:

Permittee: AUSTIN, CITY OF (WALNUT CREEK)
 Permittee Address: 7113 EAST FM 969
 AUSTIN, TX 787678859

Facility: CITY OF AUSTIN(WALNUT CREEK)
 Facility Location: 7113 EAST FM 969
 TRAVIS COUNTY
 AUSTIN, TX 787678859

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period: **From 02/01/13 to 02/28/13**

DMR Due Date: **03/20/13**

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: Meszaros
 Last Name: Greg

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	7.1								19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.	>=	6 MO MIN								19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.2					=	7.2	12 - SU	0	01/01 - Daily	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM	12 - SU	01/01 - Daily		GR - GRAB		
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1175		26 - lb/d		=	2.9	=	5.8	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV		26 - lb/d		<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI													
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	98		26 - lb/d		<	0.3	=	2.3	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV		26 - lb/d		<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	48	=	54.3	03 - MGD						0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	TM - TOTALZ

50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Value NODI																		
					Sample	=	41466	78 - gal/min												0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	114583 2HR PEAK	78 - gal/min														99/99 - Continuous	TM - TOTALZ
					Value NODI																		
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	52.7	03 - MGD															
					Permit Req.	<=	75 ANNL AVG	03 - MGD												99/99 - Continuous	TM - TOTALZ		
					Value NODI																		
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample						=	0	19 - mg/L										
					Permit Req.																	01/01 - Daily	GR - GRAB
					Value NODI																		
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1.1	19 - mg/L											
					Permit Req.																	01/01 - Daily	GR - GRAB
					Value NODI																		
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							=	10		=	88	30 - MPN/100mL						
					Permit Req.																	05/WK - Five Per Week	GR - GRAB
					Value NODI																		
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	826	26 - lb/d				<	2.1	=	3	19 - mg/L							
					Permit Req.	<=	6255 DAILY AV	26 - lb/d														01/01 - Daily	CP - COMPOS
					Value NODI																		

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E. Coli: Units reported in MPN/100mL, not CFU/100mL. TSS, cBOD 2/27/13: Sampling Error (SE) due to the sample acidified by mistake during the composite sampling process.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-03-14 10:17 (Time Zone: -05:00)