

## DMR Copy of Record

### Permit

Permit #: **TX0046981**  
 Major:

Permittee: AUSTIN, CITY OF (WALNUT CREEK)  
 Permittee Address: 7113 EAST FM 969  
 AUSTIN, TX 787678859

Facility: CITY OF AUSTIN(WALNUT CREEK)  
 Facility Location: 7113 EAST FM 969  
 TRAVIS COUNTY  
 AUSTIN, TX 787678859

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY-OUTFALL 001

### Report Dates & Status

Monitoring Period: **From 07/01/13 to 07/31/13**

DMR Due Date: **08/20/13**

Status: **NetDMR Validated**

### Considerations for Form Completion

### Principal Executive Officer

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

### No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	6.2				19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	6 MO MIN						19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.4		=	7.1	12 - SU	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	757		26 - lb/d			=	1.8	=	4	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV		26 - lb/d		<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/01 - Daily		CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	86.1		26 - lb/d			<	0.2	=	0.4	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV		26 - lb/d		<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L	01/01 - Daily		CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	50.3	=	60.4	03 - MGD						0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	TM - TOTALZ	

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type						
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units									
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Value NODI												0	99/99 - Continuous	TM - TOTALZ						
					Sample			=	52594	78 - gal/min															
					Permit Req.			<=	114583 2HR PEAK	78 - gal/min															
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Value NODI												0	99/99 - Continuous	TM - TOTALZ						
					Sample	=	50.8			03 - MGD															
					Permit Req.	<=	75 ANNL AVG			03 - MGD															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Value NODI												0	01/01 - Daily	GR - GRAB						
					Sample						=	0	19 - mg/L												
					Permit Req.						<	.1 INST MAX	19 - mg/L												
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Value NODI												0	01/01 - Daily	GR - GRAB						
					Sample						=	1.1	19 - mg/L												
					Permit Req.						>=	1 MINIMUM	19 - mg/L												
X 51040	E. coli	1 - Effluent Gross	0	--	Value NODI												0	05/WK - Five Per Week	GR - GRAB						
					Sample						=	40	=	411	30 - MPN/100mL										
					Permit Req.								Req Mon DAILY AV			Req Mon DAILY MX				3Z - CFU/100mL					
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Value NODI												0	01/01 - Daily	CP - COMPOS						
					Sample	<	840			26 - lb/d			<	2	<	2				19 - mg/L					
					Permit Req.	<=	6255 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX				19 - mg/L					
					Value NODI																				

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E. Coli: Units reported in MPN/100mL not CFU/100mL.

***Attachments***

*No attachments.*

***Report Last Saved By***

***AUSTIN, CITY OF (WALNUT CREEK)***

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-08-14 13:47 (Time Zone: -05:00)