

## DMR Copy of Record

<b>Permit</b>		<b>Permittee:</b> AUSTIN, CITY OF (WALNUT CREEK)		<b>Facility:</b> CITY OF AUSTIN(WALNUT CREEK)	
<b>Permit #:</b> TX0046981	<b>Major:</b>	<b>Permittee Address:</b> 7113 EAST FM 969 AUSTIN, TX 787678859	<b>Facility Location:</b> 7113 EAST FM 969 TRAVIS COUNTY AUSTIN, TX 787678859		
<b>Permitted Feature:</b> 001 External Outfall	<b>Discharge:</b> 001-A DOMESTIC FACILITY-OUTFALL 001				

<b>Report Dates &amp; Status</b>		<b>Monitoring Period:</b> From 11/01/13 to 11/30/13	<b>DMR Due Date:</b> 12/20/13	<b>Status:</b> NetDMR Validated
----------------------------------	--	---	-------------------------------	---------------------------------

**Considerations for Form Completion**

<b>Principal Executive Officer</b>		<b>First Name:</b> Greg	<b>Title:</b> Director	<b>Telephone:</b> 512-972-0101
<b>Last Name:</b> Meszaros				

**No Data Indicator (NODI)**  
Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7										19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.	>=	6 MO MIN										19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.8					=	7.3				12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM				12 - SU	01/01 - Daily		GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2292			26 - lb/d		=	3.9	=	9		19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d		<=	15 DAILY AV	<=	40 DAILY MX		19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	142			26 - lb/d		<	0.2	=	1.8		19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d		<=	2 DAILY AV	<=	10 DAILY MX		19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	68.1	=	116.5	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV			Req Mon DAILY MX	03 - MGD								99/99 - Continuous	TM - TOTALZ
					Value NODI															

X 50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample	=	180611	78 - gal/min									99/99 - Continuous	TM - TOTALZ			
					Permit Req.	<=	114583 2HR PEAK	78 - gal/min											99/99 - Continuous	TM - TOTALZ	
					Value NODI																
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	52.5	03 - MGD										99/99 - Continuous	TM - TOTALZ		
					Permit Req.	<=	75 ANNL AVG	03 - MGD											99/99 - Continuous	TM - TOTALZ	
					Value NODI																
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0	19 - mg/L			01/01 - Daily	GR - GRAB			
					Permit Req.	<											.1 INST MAX	19 - mg/L	0	01/01 - Daily	GR - GRAB
					Value NODI																
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample				=	1				19 - mg/L		01/01 - Daily	GR - GRAB				
					Permit Req.	>=											19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Value NODI																
X 51040	E. coli	1 - Effluent Gross	0	--	Sample				=	9		=	146	30 - MPN/100mL			05/WK - Five Per Week	GR - GRAB			
					Permit Req.																
					Value NODI																
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	1113	26 - lb/d				<	2	<	2	19 - mg/L		01/01 - Daily	CP - COMPOS		
					Permit Req.	<=	6255 DAILY AV	26 - lb/d													
					Value NODI																

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	
50050	Flow, in conduit or thru treatment plant	P - See Comments	Quantity or Loading Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	

**Comments**

E. coli: Units reported in MPN/100ml, not CFU/100ml Flow: Peak flow exceeded on 11/1/13 due to high rainfall event, TCEQ notified CBOD: Results LE (Lab Error) on 11/1/13 and 11/5/13 due to the seed control samples failing to deplete by the required 2mg/L CBOD: Result LE (Lab Error) on 11/30/13 due to the incubator falling below 19 C

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF (WALNUT CREEK)**

User: jane.burazer@austintexas.gov

Date/Time: 2013-12-13 10:14 (Time Zone: -06:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov