

DMR Copy of Record

Permit

Permit #: **TX0046981**
 Major:

Permittee: AUSTIN, CITY OF (WALNUT CREEK)
 Permittee Address: 7113 EAST FM 969
 AUSTIN, TX 787678859

Facility: CITY OF AUSTIN(WALNUT CREEK)
 Facility Location: 7113 EAST FM 969
 TRAVIS COUNTY
 AUSTIN, TX 787678859

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period: **From 09/01/13 to 09/30/13**

DMR Due Date: **10/20/13**

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	6.4						19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.					>=	6 MO MIN						19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.5		=	7.3		12 - SU	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	6 MINIMUM		<=	9 MAXIMUM		12 - SU		01/01 - Daily	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1695					=	3.8	=	9.6		19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV					<=	15 DAILY AV	<=	40 DAILY MX		19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	449					<	1	=	3.9		19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV					<=	2 DAILY AV	<=	10 DAILY MX		19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	51.7	=	83.6									0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV													99/99 - Continuous

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type				
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units			
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Value NODI												0	99/99 - Continuous	TM - TOTALZ			
					Sample			=	76389	78 - gal/min												
					Permit Req.			<=	114583 2HR PEAK	78 - gal/min												
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Value NODI												0	99/99 - Continuous	TM - TOTALZ			
					Sample	=	50.4			03 - MGD												
					Permit Req.	<=	75 ANNL AVG			03 - MGD												
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Value NODI												0	01/01 - Daily	GR - GRAB			
					Sample						=	0	19 - mg/L									
					Permit Req.						<	.1 INST MAX	19 - mg/L									
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Value NODI												0	01/01 - Daily	GR - GRAB			
					Sample						=	1.1	19 - mg/L									
					Permit Req.						>=	1 MINIMUM	19 - mg/L									
X 51040	E. coli	1 - Effluent Gross	0	--	Value NODI												0	21/30 - 21 Per Month	GR - GRAB			
					Sample						=	45	=	308	30 - MPN/100mL							
					Permit Req.										Req Mon DAILY AV					Req Mon DAILY MX	3Z - CFU/100mL	
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Value NODI												0	01/01 - Daily	CP - COMPOS			
					Sample	<	867			26 - lb/d			<	2	=	2.2				19 - mg/L		
					Permit Req.	<=	6255 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX				19 - mg/L		

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E. coli: Units reported in MPN/100ml, not CFU/100ml

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2013-10-13 14:07 (Time Zone: -05:00)