

DMR Copy of Record

Permit

Permit #: **TX0124800**
 Major:

Permittee: AUSTIN, CITY OF
 Permittee Address: 4800' E INTX BLUE BLUFF RD & AUSTIN, TX 78767

Facility: WILD HORSE RANCH WWTP
 Facility Location: 4800' E INTX BLUE BLUFF RD & LINDEL LN, TRAVIS COUNTY AUSTIN, TX 78767

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 08/01/13 to 08/31/13**

DMR Due Date: **09/20/13**

Status: **NetDMR Validated**

Considerations for Form Completion

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units					
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	6.7						19 - mg/L	0	18/30 - 18 Per Month	GR - GRAB
					Permit Req.						>=	5 MO MIN						19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.9			=	7.5	12 - SU	0	20/30 - Twenty Per Month	GR - GRAB	
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/30 - Twice Per Month	GR - GRAB	
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	1			26 - lb/d			<	0.7	=	1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	31 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI																
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	0.4			26 - lb/d			<	0.2	=	0.8	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	13 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	<	0.08			26 - lb/d			<	0.05	<	0.05	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
					Permit Req.	<=	6.3 DAILY AV						<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.18	=	0.5	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NODI															
					Sample								<	1	<	1	30 - MPN/100mL		01/01 - Daily	GR - GRAB
X 51040	E. coli	1 - Effluent Gross	0	--	Permit Req.								<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL	0	01/01 - Daily	GR - GRAB
					Value NODI															
					Sample	<	3.1			26 - lb/d			<	2	<	2	19 - mg/L		01/07 - Weekly	CP - COMPOS
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Permit Req.	<=	31 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E. Coli: Units reported in MPN/100ml, not CFU/100ml E. Coli: 8/26/13 LE (Lab Error) SAMPLE WAS SET UP BUT NOT READ OFF

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Date/Time:

2013-09-12 17:44 (Time Zone: -05:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov