

DMR Copy of Record

Permit

Permit #:
Major:

TX0124800

Permittee:
Permittee Address:

AUSTIN, CITY OF
4800' E INTX BLUE BLUFF RD &
AUSTIN, TX 78767

Facility:
Facility Location:

WILD HORSE RANCH WWTP
4800' E INTX BLUE BLUFF RD &
LINDEL LN, TRAVIS COUNTY
AUSTIN, TX 78767

Permitted Feature:

001
External Outfall

Discharge:

001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period:

From 11/01/13 to 11/30/13

DMR Due Date:

12/20/13

Status:

NetDMR Validated

Considerations for Form Completion

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

Principal Executive Officer

First Name:
Last Name:

Greg
Meszaros

Title:

Director

Telephone:

512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.3					19 - mg/L	0	18/30 - 18 Per Month	GR - GRAB
					Permit Req.						>=	5 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7			=	7.3	12 - SU	0	19/30 - 19 Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/30 - Twice Per Month	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	0.9			26 - lb/d			<	0.5	<	0.5	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	0.2			26 - lb/d			<	0.1	<	0.1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	13 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	<	0.09			26 - lb/d			<	0.05	<	0.05	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	6.3 DAILY AV			26 - lb/d			<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS

					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.22	=	0.43	03 - MGD								99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	TM - TOTALZ
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	1	=	2	30 - MPN/100mL		01/01 - Daily	GR - GRAB
					Permit Req.							<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL	0	01/01 - Daily	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	3.6			26 - lb/d		<	2	<	2	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV			26 - lb/d		<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	

Comments

E. coli: Units reported in MPN/100mL, not CFU/100mL CBOD result for 11/5/13 sample was a Laboratory Error (LE) due to the seed control samples failing to deplete by the required 2 mg/L.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User:	jane.burazer@austintexas.gov	Date/Time:	2013-12-13 10:09 (Time Zone: -06:00)
Name:	Jane Burazer		
E-Mail:	jane.burazer@austintexas.gov		