

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF**  
**AUSTIN WATER UTILITY**  
**P.O. BOX 1088**  
**AUSTIN, TEXAS 78767-8865**



<b>40B</b>	<b>WQ0010543-012</b>	<b>01</b>	<b>1   3</b>	<b>0   3</b>	<b>19743</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE	UNITS					
<b>00085342</b> <b>TRANSFER</b>	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
<b>DAYS/MON</b>	PERMITTED				11	2/WEEK	03	GRABPKLOAD
<b>316164024</b> <b>FEC. COLI</b>	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
<b>DLY AVG</b>	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
<b>316164030</b> <b>FEC. COLI</b>	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
<b>IND GRAB</b>	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
<b>500507124</b> <b>FLOW</b>	REPORTED	0	MGD	0	NA	NA	NA	NA
<b>DLY AVG</b>	PERMITTED				02	CONT	11	CONT
<b>800821024</b> <b>BOD CARB</b>	REPORTED	0	MG/L	0	NA	NA	NA	NA
<b>DLY AVG</b>	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
<b>820796624</b> <b>TURBIDITY</b>	REPORTED	0	NTU	0	NA	NA	NA	NA
<b>30DAYAVG</b>	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
<b>NUMBER OF OPERATOR CERTIFICATE</b>	REPORTED	WW0011708	NUMBER	0	01		NA	
	PERMITTED				01	01	NA	NA
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	REPORTED	15/05/12	DATE	0	01		NA	
	PERMITTED				01	01	NA	NA
<b>CLASS OF OPERATOR CERTIFICATE</b>	REPORTED	B	LETTER	0	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)  
 E. coli Limits: DLY AVG: 200 / 100mL, IND GRAB: 800 / 100 mL

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE		
	<b>Randall Swenson</b>	<i>Randall Swenson</i>	1   3	0   4	0   9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR	MO.	DAY
5   1   2	9   7   2	0   1   0   1	1   3	0   4	0   9
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR	MO. DAY
		<i>Greg Meszaros</i>			



# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF**  
**AUSTIN WATER UTILITY**  
**P.O. BOX 1088**  
**AUSTIN, TEXAS 78767-8865**



<b>40B</b>	<b>WQ0010543-012</b>	<b>01</b>	<b>1   3</b>	<b>0   3</b>	<b>19742</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **OTFL 900 RECALIMED WATER TYPE II**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	VALUE	UNITS				
<b>00085342</b> <b>TRANSFER</b> <b>DAYS/MON</b>	REPORTED	<b>31</b>	<b>DAY</b>	<b>0</b>	<b>01</b>		<b>01</b>
	PERMITTED			<b>01</b>	<b>NA</b>		<b>01</b>
<b>316164024</b> <b>FEC. COLI</b> <b>DLY AVG</b>	REPORTED	<b>NA</b>	<b>#/100 ML</b>	<b>0</b>	<b>11</b>	<b>NA</b>	<b>03</b>
	PERMITTED	<b>200.000</b>		<b>14</b>	<b>1/WEEK</b>		<b>03</b>
<b>316164030</b> <b>FEC. COLI</b> <b>IND GRAB</b>	REPORTED	<b>NA</b>	<b>#/100 ML</b>	<b>0</b>	<b>11</b>	<b>NA</b>	<b>03</b>
	PERMITTED	<b>800.000</b>		<b>14</b>	<b>1/WEEK</b>		<b>03</b>
<b>500507124</b> <b>FLOW</b> <b>DLY AVG</b>	REPORTED	<b>2.75</b>	<b>MGD</b>	<b>0</b>	<b>02</b>	<b>CONT</b>	<b>11</b>
	PERMITTED			<b>14</b>	<b>1/WEEK</b>		<b>12</b>
<b>800821024</b> <b>BOD CARB</b> <b>DLY AVG</b>	REPORTED	<b>&lt;2.4</b>	<b>MG/L</b>	<b>0</b>	<b>11</b>	<b>2/WEEK</b>	<b>03</b>
	PERMITTED	<b>15.000</b>		<b>14</b>	<b>1/WEEK</b>		<b>03</b>
<b>NUMBER</b> <b>OF OPERATOR</b> <b>CERTIFICATE</b>	REPORTED	<b>WW0011708</b>	<b>NUMBER</b>	<b>0</b>	<b>01</b>		<b>NA</b>
	PERMITTED			<b>01</b>	<b>01</b>		<b>NA</b>
<b>EXPIRATION</b> <b>OF OPERATOR</b> <b>CERTIFICATE</b>	REPORTED	<b>15/05/12</b>	<b>DATE</b>	<b>0</b>	<b>01</b>		<b>NA</b>
	PERMITTED			<b>01</b>	<b>01</b>		<b>NA</b>
<b>CLASS</b> <b>OF OPERATOR</b> <b>CERTIFICATE</b>	REPORTED	<b>B</b>	<b>LETTER</b>	<b>0</b>	<b>01</b>		<b>NA</b>
	PERMITTED			<b>01</b>	<b>01</b>		<b>NA</b>
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889. South Austin Regional WWTP transferred reclaimed water for 31 days. ECOLI grabs collected 2/week: DLY AVG = 12 MPN/100mL; IND GRAB Max = 37 MPN/100mL. E. coli limits: DLY AVG: 200 / 100mL. IND GRAB: 800 / 100 mL. FCOLI not analyzed.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	<b>Randall Swenson</b>		<b>1   3   0   4   0   9</b>
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
<b>5   1   2   9   7   2   0   1   0   1</b>	<b>Greg Meszaros, Director</b>		<b>1   3   0   4   0   9</b>
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY



# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF**  
**AUSTIN WATER UTILITY**  
**P.O. BOX 1088**  
**AUSTIN, TEXAS 78767-8865**

Page 3 of 3



<b>40B</b>	<b>WQ0010543-012</b>	<b>01</b>	<b>1   3</b>	<b>0   3</b>	<b>19744</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OTFL 001 AND RECLAIMED WATER**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS	01	01	01
<b>500507124</b>							
<b>FLOW</b>	REPORTED	<b>0</b>	<b>0</b>	<b>01</b>		<b>01</b>	
<b>DAILY AVG</b>	PERMITTED			<b>01</b>	<b>NA</b>	<b>01</b>	<b>NA</b>
<b>NUMBER OF OPERATOR CERTIFICATE</b>	REPORTED	<b>WW0011708</b>	<b>0</b>	<b>01</b>		<b>NA</b>	
	PERMITTED			<b>01</b>	<b>01</b>	<b>NA</b>	<b>NA</b>
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	REPORTED	<b>15/05/12</b>	<b>0</b>	<b>01</b>		<b>NA</b>	
	PERMITTED			<b>01</b>	<b>01</b>	<b>NA</b>	<b>NA</b>
<b>CLASS OF OPERATOR CERTIFICATE</b>	REPORTED	<b>B</b>	<b>0</b>	<b>01</b>		<b>NA</b>	
	PERMITTED			<b>01</b>	<b>01</b>	<b>NA</b>	<b>NA</b>
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	<b>Randall Swenson</b>		<b>1   3</b> <b>0   4</b> <b>0   9</b>
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
<b>5   1   2</b> <b>9   7   2</b> <b>0   1   0   1</b>	<b>Greg Meszaros, Director</b>		<b>1   3</b> <b>0   4</b> <b>0   9</b>
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY



# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	01 SET	1   3   0   3 YEAR   MO.	15650 EID
------------	--------------------------------	-----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	VALUE		UNITS	NO.	FREQUENCY	TYPE	TYPE
316164024 FEC. COLI DLY AVG	REPORTED	NA	#/100 ML	0	11	NA	03	NA
	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	NA	#/100 ML	0	11	NA	03	NA
	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	0.32	MGD	0	02	CONT	11	CONT
	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	<2.3	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	1.91	NTU	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01			NA
	PERMITTED				01	01		NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/11/12	DATE	0	01			NA
	PERMITTED				01	01		NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01			NA
	PERMITTED				01	01		NA NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)  
 Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981. Walnut Creek WWTP transferred reclaimed water for 31 days. ECOLI grabs collected 2X/week. DLY AVG = <2 MPN/100mL; IND GRAB Max = 13 MPN/100mL. E. coli Limits: DLY AVG: 20 / 100mL, IND GRAB: 75 / 100 mL. FCOLI not analyzed.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1   3   0   4   0   9 YEAR   MO.   DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR   MO.   DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director		1   3   0   4   0   9 YEAR   MO.   DAY
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER



# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 2 of 3



40B SYS	WQ0010543-011 PERMIT NUMBER	01 SET	1   3 YEAR	0   3 MO.	15651 EID
------------	--------------------------------	-----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR OTFL 900 RECLAIMED WATER TYPE II

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE	UNITS					
000085342 TRANSFER DAYS MON	REPORTED	0	DAY	0	01		01	
	PERMITTED			0	01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	200.000		0	14	1/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	800.000		0	14	1/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	0	MGD	0	NA	NA	NA	NA
	PERMITTED			0	14	1/WEEK	02	GRAB
800821024 BOD CARB DLY AVG	REPORTED	0	MG/L	0	NA	NA	NA	NA
	PERMITTED	15.000		0	14	1/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA	
	PERMITTED			0	01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/11/12	DATE	0	01		NA	
	PERMITTED			0	01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA	
	PERMITTED			0	01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1   3   0   4   0   9 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director		1   3   0   4   0   9 YEAR MO. DAY
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY



# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF**  
**AUSTIN WATER UTILITY**  
**P.O. BOX 1088**  
**AUSTIN, TEXAS 78767-8865**

Page 3 of 3



<b>40B</b>	<b>WQ0010543-011</b>	<b>01</b>	<b>1   3</b>	<b>0   3</b>	<b>15652</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OUTFALLS 001 AND RECLAIMED WATER**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
<b>500507124 FLOW</b>	REPORTED		0	MGD	01		01
<b>DAILY AVG</b>	PERMITTED				01	NA	01 NA
<b>NUMBER OF OPERATOR CERTIFICATE</b>	REPORTED		0	NUMBER	01		NA
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	PERMITTED				01	01	NA NA
<b>CLASS OF OPERATOR CERTIFICATE</b>	REPORTED		0	DATE	01		NA
	PERMITTED				01	01	NA NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

**COMMENTS AND EXPLANATIONS** *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	<b>Mike Welch</b>		<b>1   3   0   4   0   9</b>
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
<b>5   1   2   9   7   2   0   1   0   1</b>	<b>Greg Meszaros, Director</b>		<b>1   3   0   4   0   9</b>
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY