

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-012	01	1 3	0 9	19743
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR OTFL 800 RECLAIMED WATER TYPE I
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS	NA	NA	NA
000085342 TRANSFER DAYS/MON	REPORTED	0	DAY	0	NA	NA	NA
	PERMITTED			11	2/WEEK	03	GRABPKLOAD
316164024 FEC. COLI DLY AVG	REPORTED	0	#/100 ML	0	NA	NA	NA
	PERMITTED	20.000		11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	0	#/100 ML	0	NA	NA	NA
	PERMITTED	75.000		11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	0	MGD	0	NA	NA	NA
	PERMITTED			02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	0	MG/L	0	NA	NA	NA
	PERMITTED	5.000		11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	0	NTU	0	NA	NA	NA
	PERMITTED	3.000		11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		NA
	PERMITTED			01	01		NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/05/12	DATE	0	01		NA
	PERMITTED			01	01		NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		NA
	PERMITTED			01	01		NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE		
	Randall Swenson		1 3	1 0	0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR	MO.	DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 3	1 0	0 9
AREA CODE	NUMBER	EXECUTIVE OFFICER	YEAR	MO.	DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

Page 2 of 3



40B SYS	WQ0010543-012 PERMIT NUMBER	01 SET	1 3 YEAR	0 9 MO.	19742 EID
------------	--------------------------------	-----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **OTFL 900 RECLAIMED WATER TYPE II**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	REPORTED	VALUE	UNITS				
000085342 TRANSFER DAYS/MON	REPORTED	30	DAY	0	01		01
	PERMITTED			01	NA		01 NA
316164024 FEC. COLI DLY AVG	REPORTED	NA	#/100 ML	0	11	NA	03 NA
	PERMITTED	200.000		14	1/WEEK		03 GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	NA	#/100 ML	0	11	NA	03 NA
	PERMITTED	800.000		14	1/WEEK		03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	2.66	MGD	0	02	CONT	11 CONT
	PERMITTED			14	1/WEEK		12 INSTANT
800821024 BOD CARB DLY AVG	REPORTED	<2.0	MG/L	0	11	2/WEEK	03 GRABPKLOAD
	PERMITTED	15.000		14	1/WEEK		03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		NA
	PERMITTED			01	01		NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/05/12	DATE	0	01		NA
	PERMITTED			01	01		NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		NA
	PERMITTED			01	01		NA NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889. South Austin Regional WWTP transferred reclaimed water for 30 days. ECOLI grabs collected 2/week: DLY AVG = <6 MPN/100mL; IND GRAB Max = 107 MPN/100mL. E. coli Limits: DLY AVG: 200 / 100mL. IND GRAB: 800 / 100 mL. FCOLI not analyzed.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1 3 1 0 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1 3 1 0 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-012	01	1 3	0 9	19744
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OTFL 001 AND RECLAIMED WATER**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
500507124 FLOW	REPORTED		48.4	MGD	0 01		01	
DAILY AVG	PERMITTED				01	NA	01	NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0011708	NUMBER	0 01		NA	
	PERMITTED				01 01		NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		15/05/12	DATE	0 01		NA	
	PERMITTED				01 01		NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		B	LETTER	0 01		NA	
	PERMITTED				01 01		NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE		
	Randall Swenson	<i>Randall Swenson</i>	1 3	1 0	0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR	MO.	DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director	<i>Greg Meszaros</i>	1 3	1 0	0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR	MO.	DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	01 SET	1 3 0 9 YEAR MO.	15650 EID
------------	--------------------------------	-----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE	UNITS					
316164024 FEC. COLI DLY AVG	REPORTED	NA	#/100 ML	0	11	NA	03	NA
	PERMITTED	20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	NA	#/100 ML	0	11	NA	03	NA
	PERMITTED	75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	1.54	MGD	0	02	CONT	11	CONT
	PERMITTED				02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	<2.0	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	1.79	NTU	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA	
	PERMITTED				01	01	NA	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/11/12	DATE	0	01		NA	
	PERMITTED				01	01	NA	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)
 Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981. Walnut Creek WWTP transferred reclaimed water for 30 days. ECOLI grabs collected 2X/week. DLY AVG = <1 MPN/100mL; IND GRAB Max = 6 MPN/100mL. E. coli Limits: DLY AVG: 20 / 100mL, IND GRAB: 75 / 100 mL. FCOLI not analyzed.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 3 1 0 0 9 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 3 1 0 0 9 YEAR MO. DAY
AREA CODE NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	01 SET	1 3 0 9 YEAR MO.	15651 EID
------------	--------------------------------	-----------	-----------------------------	--------------

THIS REPORT TO BE USED FOR **OTFL 900 RECLAIMED WATER TYPE II**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS			
000085342 TRANSFER DAYS MON	REPORTED	0	DAY	0	01		01
	PERMITTED				01	NA	01
316164024 FEC. COLI DLY AVG	REPORTED	0	#/100 ML	0	NA	NA	NA
	PERMITTED	200.000			14	1/WEEK	03
316164030 FEC. COLI IND GRAB	REPORTED	0	#/100 ML	0	NA	NA	NA
	PERMITTED	800.000			14	1/WEEK	03
500507124 FLOW DLY AVG	REPORTED	0	MGD	0	NA	NA	NA
	PERMITTED				14	1/WEEK	02
800821024 BOD CARB DLY AVG	REPORTED	0	MG/L	0	NA	NA	NA
	PERMITTED	15.000			14	1/WEEK	03
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA
	PERMITTED				01	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/11/12	DATE	0	01		NA
	PERMITTED				01	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA
	PERMITTED				01	01	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 3 1 0 0 9 YEAR MO. DAY
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 3 1 0 0 9 YEAR MO. DAY
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

Page 3 of 3



40B	WQ0010543-011	01	1 3	0 9	15652
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OUTFALLS 001 AND RECLAIMED WATER**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
500507124 FLOW	REPORTED		53.2	MGD	0	01		01
DAILY AVG	PERMITTED					01	NA	01 NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0018247	NUMBER	0	01		NA
	PERMITTED					01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		15/11/12	DATE	0	01		NA
	PERMITTED					01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0	01		NA
	PERMITTED					01	01	NA NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	Mike Welch		1 3 1 0 0 9
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 3 1 0 0 9
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY