

DMR Copy of Record

Permit

Permit #:
Major:

TX0097870

Permittee:
Permittee Address:

AUSTIN, CITY OF
1.4M N DESSAU RD&YAGER LANE
AUSTIN, TX 78746

Facility:
Facility Location:

DESSAU WWTF
1.4M N DESSAU RD AND YAGER LANE
AUSTIN, TX 78746

Permitted Feature:

001
External Outfall

Discharge:

001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period:

From 01/01/14 to 01/31/14

DMR Due Date:

02/20/14

Status:

NetDMR Validated

Considerations for Form Completion

WQ0012971-001

Principal Executive Officer

First Name:
Last Name:

Greg
Meszaros

Title:

Director

Telephone:

512-972-0101

No Data Indicator (NODI)

Form NODI: --

file:///C:/Users/CourtrightK/Documents/netdmr_cor_zips_2014_03_13_13_04_42/TX0097870_001-A_mped2014_01_31_subd2014_02_13_n6/dmrSubmission.xml[3/13/2014 1:07:48 PM]

					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.4			=	2	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		01/01 - Daily	GR - GRAB	
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	1	=	3	30 - MPN/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.							<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL		01/07 - Weekly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	2.7			26 - lb/d			<	2.3	=	3.1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	42 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	

Comments

E. coli: Units reported in MPN/100, not CFU/100ml

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User:	jane.burazer@austintexas.gov	Date/Time:	2014-02-13 17:43 (Time Zone: -06:00)
Name:	Jane Burazer		
E-Mail:	jane.burazer@austintexas.gov		