DMR Copy of Record

Permit

Permit #: **TX0067466**
Major:
Permitted Feature: 001 External Outfall

Permittee: AUSTIN, CITY OF
Permittee Address: 8250 CITATION AVE,2400F E. FMR AUSTIN, TX 787670000
Discharge: **001-A** DOMESTIC FACILITY - 001

Facility: THOROUGHBRED FARMS WWTP
Facility Location: 8250 CITATION AVE,2400F E. FMR 973 AUSTIN, TX 787670000

Report Dates & Status

Monitoring Period: **From 12/01/14 to 12/31/14**
DMR Due Date: **01/20/15**
Status: **NetDMR Validated & Complete**

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
Last Name: Meszaros
Title: Director
Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	6.7					19 - mg/L	0	09/30 - Nine Per Month	GR - GRAB
					Permit Req.						>=	2 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.3			26 - lb/d			<	2.1	=	2.3	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.8			=	8	12 - SU	0	23/30 - 23 Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.3			26 - lb/d			=	2.3	=	5.1	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
										03 -									01/01 -	IN -

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	**Sample**	=	0.016	=	0.02	MGD								0	Daily	INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD									05/WK - Five Per Week	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	**Sample**						=	1			=	3.8	19 - mg/L	0	25/30 - 25 Per Month	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analsyis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov | Date/Time: 2015-08-07 11:47 (Time Zone: -05:00)

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov