

## DMR Copy of Record

## Permit

Permit #: TX0067466

Major: ☐

Permittee: AUSTIN, CITY OF

Permittee Address: 8250 CITATION AVE,2400F E. FMR  
AUSTIN, TX 787670000

Facility: THOROUGHbred FARMS WWTP

Facility Location: 8250 CITATION AVE,2400F E. FMR 973  
AUSTIN, TX 787670000Permitted Feature: 001  
External OutfallDischarge: 001-A  
DOMESTIC FACILITY - 001

## Report Dates &amp; Status

Monitoring Period: From 02/01/14 to 02/28/14

DMR Due Date: 03/20/14

Status: NetDMR Validated

## Considerations for Form Completion

## Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

## No Data Indicator (NODI)

Form NODI: --

| Parameter |                         | Monitoring Location | Season # | Param. NODI |             | Quantity or Loading |             |             |         |           | Quality or Concentration |           |             |             |             |             | # of Ex.  | Frequency of Analysis | Sample Type          |              |
|-----------|-------------------------|---------------------|----------|-------------|-------------|---------------------|-------------|-------------|---------|-----------|--------------------------|-----------|-------------|-------------|-------------|-------------|-----------|-----------------------|----------------------|--------------|
| Code      | Name                    |                     |          |             |             | Qualifier 1         | Value 1     | Qualifier 2 | Value 2 | Units     | Qualifier 1              | Value 1   | Qualifier 2 | Value 2     | Qualifier 3 | Value 3     |           |                       |                      | Units        |
| 00300     | Oxygen, dissolved [DO]  | 1 - Effluent Gross  | 0        | --          | Sample      |                     |             |             |         |           | =                        | 4.2       |             |             |             |             | 19 - mg/L | 0                     | 16/30 - 16 Per Month | GR - GRAB    |
|           |                         |                     |          |             | Permit Req. |                     |             |             |         |           | >=                       | 2 MO MIN  |             |             |             |             | 19 - mg/L |                       | 01/07 - Weekly       | GR - GRAB    |
|           |                         |                     |          |             | Value NODI  |                     |             |             |         |           |                          |           |             |             |             |             |           |                       |                      |              |
| 00310     | BOD, 5-day, 20 deg. C   | 1 - Effluent Gross  | 0        | --          | Sample      | <                   | 0.9         |             |         | 26 - lb/d |                          |           | <           | 4.7         | =           | 12.9        | 19 - mg/L | 0                     | 01/07 - Weekly       | GR - GRAB    |
|           |                         |                     |          |             | Permit Req. | <=                  | 11 DAILY AV |             |         | 26 - lb/d |                          |           | <=          | 20 DAILY AV | <=          | 65 SINGGRAB | 19 - mg/L |                       | 01/07 - Weekly       | GR - GRAB    |
|           |                         |                     |          |             | Value NODI  |                     |             |             |         |           |                          |           |             |             |             |             |           |                       |                      |              |
| 00400     | pH                      | 1 - Effluent Gross  | 0        | --          | Sample      |                     |             |             |         |           | =                        | 6.9       |             |             | =           | 7.7         | 12 - SU   | 0                     | 19/30 - 19 Per Month | GR - GRAB    |
|           |                         |                     |          |             | Permit Req. |                     |             |             |         |           | >=                       | 6 MINIMUM |             |             | <=          | 9 MAXIMUM   | 12 - SU   |                       | 01/30 - Monthly      | GR - GRAB    |
|           |                         |                     |          |             | Value NODI  |                     |             |             |         |           |                          |           |             |             |             |             |           |                       |                      |              |
| 00530     | Solids, total suspended | 1 - Effluent Gross  | 0        | --          | Sample      | =                   | 1.8         |             |         | 26 - lb/d |                          |           | =           | 9.4         | =           | 13.6        | 19 - mg/L | 0                     | 01/07 - Weekly       | GR - GRAB    |
|           |                         |                     |          |             | Permit Req. | <=                  | 11 DAILY AV |             |         | 26 - lb/d |                          |           | <=          | 20 DAILY AV | <=          | 65 SINGGRAB | 19 - mg/L |                       | 01/07 - Weekly       | GR - GRAB    |
|           |                         |                     |          |             | Value NODI  |                     |             |             |         |           |                          |           |             |             |             |             |           |                       |                      |              |
| 50050     | Flow, in conduit or     | 1 - Effluent Gross  | 0        | --          | Sample      | =                   | 0.025       | =           | 0.03    | 03 - MGD  |                          |           |             |             |             |             |           | 0                     | 01/01 - Daily        | IN - INSTANT |

| Parameter |                          | Monitoring Location | Season # | Param. NODI |             | Quantity or Loading |               |             |                  |          | Quality or Concentration |          |             |         |             |          | # of Ex.  | Frequency of Analysis | Sample Type |
|-----------|--------------------------|---------------------|----------|-------------|-------------|---------------------|---------------|-------------|------------------|----------|--------------------------|----------|-------------|---------|-------------|----------|-----------|-----------------------|-------------|
| Code      | Name                     |                     |          |             |             | Qualifier 1         | Value 1       | Qualifier 2 | Value 2          | Units    | Qualifier 1              | Value 1  | Qualifier 2 | Value 2 | Qualifier 3 | Value 3  | Units     |                       |             |
|           | thru treatment plant     |                     |          |             | Permit Req. | <=                  | .065 DAILY AV |             | Req Mon DAILY MX | 03 - MGD |                          |          |             |         |             |          |           | 05/WK - Five Per Week | IN - INSTAN |
|           |                          |                     |          |             | Value NODI  |                     |               |             |                  |          |                          |          |             |         |             |          |           |                       |             |
|           |                          |                     |          |             | Sample      |                     |               |             |                  |          | =                        | 1.7      |             |         | =           | 2.4      | 19 - mg/L | 05/WK - Five Per Week | GR - GRAB   |
| 50060     | Chlorine, total residual | 1 - Effluent Gross  | 0        | --          | Permit Req. |                     |               |             |                  |          | >=                       | 1 MO MIN |             |         | <=          | 4 MO MAX | 19 - mg/L | 05/WK - Five Per Week | GR - GRAB   |
|           |                          |                     |          |             | Value NODI  |                     |               |             |                  |          |                          |          |             |         |             |          |           |                       |             |

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

The E. coli single grab limit of 374 MPN/100ml was exceeded on 2-12-14

**Attachments**

No attachments.

**Report Last Saved By****AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2014-03-14 10:21 (Time Zone: -05:00)