

Permit

Major:

Facility:	THOROUGHBRED FARMS WWTP
Facility Location:	8250 CITATION AVE,2400F E. FMR 973 AUSTIN, TX 787670000

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Status: NetDMR Validated

Telephone: 512-972-0101

Form NODI: --

[illegible]

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
	Flow, in conduit or thru treatment plant	1 - Effluent Gross								03 - MGD								99/99 - Continuous	IN - INSTAN	
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - MGD								05/WK - Five Per Week	IN - INSTAN	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						=	1.1			=	4	19 - mg/L	0	23/30 - 23 Per Month	GR - GRAB
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

The TBFEFF E. coli result from 5/27/14 was >2419.6 MPN/100mL which exceeds the single grab limit of 394 MPN/100mL.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2014-06-13 11:19 (Time Zone: -05:00)