

## DMR Copy of Record

## Permit

**Permit #:** TX0046981  
**Major:** ☒

**Permittee:** AUSTIN, CITY OF (WALNUT CREEK)  
**Permittee Address:** 7113 EAST FM 969  
 AUSTIN, TX 787678859

**Facility:** CITY OF AUSTIN(WALNUT CREEK)  
**Facility Location:** 7113 EAST FM 969  
 TRAVIS COUNTY  
 AUSTIN, TX 787678859

**Permitted Feature:** 001  
 External Outfall

**Discharge:** 001-A  
 DOMESTIC FACILITY-OUTFALL 001

## Report Dates &amp; Status

**Monitoring Period:** From 02/01/14 to 02/28/14

**DMR Due Date:** 03/20/14

**Status:** NetDMR Validated

## Considerations for Form Completion

## Principal Executive Officer

**First Name:** Greg  
**Last Name:** Meszaros

**Title:** Director

**Telephone:** 512-972-0101

## No Data Indicator (NODI)

**Form NODI:** --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.6					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.7			=	7.2	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2981			26 - lb/d			=	8	=	22.8	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	251			26 - lb/d			<	0.7	=	3.7	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	45	=	48	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	52083	78 - gal/min								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.			<=	114583 2HR PEAK	78 - gal/min									99/99 - Continuous	TM - TOTALZ
					Value NODI															
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	52			03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	75 ANNL AVG			03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample										=	0	19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.										<	.1 INST MAX	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample						=	1					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	1 MINIMUM					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample								<	3	=	50	30 - MPN/100mL	0	21/30 - 21 Per Month	GR - GRAB
					Permit Req.									Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL		05/WK - Five Per Week	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	965			26 - lb/d			<	2.6	=	5	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	6255 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E.Coli: Units reported in MPN/100 mL, not CFU/100 mL. E.coli: Sample collected Feb. 6 given a result of Laboratory Error (LE) due to sample not being examined in the allowable timeframe

**Attachments**

No attachments.

**Certification Statement**

I certify under penalty of law that this submission was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are criminal penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. By entering my password and security question answer and pressing the Submit button, I agree that:

1. I am Jane Burazer.
2. I have not violated any term in my Electronic Signature Agreement.
3. I am otherwise without any reason to believe that the confidentiality of my password has been compromised now or at any time prior to this submission.
4. I have the authority to submit these data on behalf of the listed facilities.
5. This action constitutes an electronic signature equivalent to my written signature.
6. I understand that this attestation of fact pertains to the implementation, oversight, and enforcement of a federal environmental program and must be true to the best of my knowledge.

**Submission Information**

Name:	Jane Burazer	Date/Time:	2014-03-14 10:33 (Time Zone: -05:00)
User:	jane.burazer@austintexas.gov	E-Mail:	jane.burazer@austintexas.gov
Submitter Telephone:	512-972-0133	Submitter Ip:	162.89.0.59
Confirmation Code:	c3e27b7f-82c4-4ae0-94b2-a6ea4d004ecd		
Submitter Hashed Password:	86d67148256edc042730e830cc275ac529c91f3201101a8ff21509d5996a263c		
DMR Hash:	44a7ea6302ce0e5138819250cc21c6dd08b4c6f61f1a8316e29ef43f1cfcb2a9		
NetDMR Certificate Id:	4		
Certificate Alias:	netdmr uat sample certificate 2		