

DMR Copy of Record

Permit

Permit #:	TX0046981	Permittee:	AUSTIN, CITY OF (WALNUT CREEK)	Facility:	CITY OF AUSTIN(WALNUT CREEK)
Major:	☒	Permittee Address:	7113 EAST FM 969 AUSTIN, TX 787678859	Facility Location:	7113 EAST FM 969 TRAVIS COUNTY AUSTIN, TX 787678859

Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY-OUTFALL 001
--------------------	-------------------------	------------	--

Report Dates & Status

Monitoring Period:	From 05/01/14 to 05/31/14	DMR Due Date:	06/20/14	Status:	NetDMR Validated
--------------------	---------------------------	---------------	----------	---------	------------------

Considerations for Form Completion

Principal Executive Officer

First Name:	Greg	Title:	Director	Telephone:	512-972-0101
Last Name:	Meszaros				

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	6.7					19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MO MIN					19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.5			=	7.3	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/01 - Daily	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	848			26 - lb/d			=	2	=	4	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	9383 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	<	309			26 - lb/d			<	0.7	=	3.9	19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Permit Req.	<=	1251 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	49.8	=	90	03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	TM - TOTALZ

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample			=	97222	78 - gal/min								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.			<=	114583 2HR PEAK	78 - gal/min							99/99 - Continuous		TM - TOTALZ	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	50.7			03 - MGD								0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	75 ANNL AVG			03 - MGD									99/99 - Continuous	TM - TOTALZ
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample									=	0	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.								<	.1 INST MAX	19 - mg/L	01/01 - Daily		GR - GRAB		
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1					19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	1 MINIMUM					19 - mg/L		01/01 - Daily	GR - GRAB	
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	6	=	40	30 - MPN/100mL	0	05/WK - Five Per Week	GR - GRAB	
					Permit Req.									Req Mon DAILY AV		Req Mon DAILY MX		3Z - CFU/100mL	05/WK - Five Per Week	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	831			26 - lb/d		<	2	<	2	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.	<=	6255 DAILY AV			26 - lb/d		<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
						☒

Comments

E. coli: Units reported in MPN/100mL, not CFU/100mL NH3-N: Sample taken 5/13/14 was given a result of SE due to the sample not being acidified upon receipt TSS: Sample taken 5/9/14 was given a result of LE due to the balance not being calibrated on day of analysis

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2014-06-13 11:28 (Time Zone: -05:00)