

Permit

Permittee: AUSTIN, CITY OF

Permittee Address: 4800' E INTX BLUE BLUFF RD &
AUSTIN, TX 78767

Facility:
Facility Location:

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

DMR Due Date: 06/20/14

Status: NetDMR Validated

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

Title:	Director
---------------	----------

Telephone: 512-972-0101

Form NODI: --

[illegible]

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	<	0.13			26 - lb/d			<	0.05	<	0.05	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	6.3 DAILY AV			26 - lb/d			<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.21	=	0.51	03 - MGD							0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - MGD								99/99 - Continuous	TM - TOTALZ	
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	1	<	1	30 - MPN/100mL	0	01/01 - Daily	GR - GRAB	
					Permit Req.							<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL		01/01 - Daily	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	5.4			26 - lb/d			<	2	<	2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E.Coli.: Units reported in MPN/100 mL, not CFU/100 mL.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2014-06-13 10:26 (Time Zone: -05:00)

