

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865**



<b>40B</b>	<b>WQ0010543-011</b>	<b>01</b>	<b>1   4</b>	<b>0   1</b>	<b>15650</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**

**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE			
	REPORTED	PERMITTED		VALUE	UNITS				
316164024 FEC. COLI DLY AVG	REPORTED		NA	#/100 ML	0	11	NA	03	NA
	PERMITTED		20.000			11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED		NA	#/100 ML	0	11	NA	03	NA
	PERMITTED		75.000			11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED		0.17	MGD	0	02	CONT	11	CONT
	PERMITTED					02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED		<2.0	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED		5.000			11	2/WEEK	03	GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED		2.27	NTU	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED		3.000			11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED		WW0018247	NUMBER	0	01			NA
	PERMITTED					01	01		NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED		15/11/12	DATE	0	01			NA
	PERMITTED					01	01		NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED		A	LETTER	0	01			NA
	PERMITTED					01	01		NA NA
	REPORTED								
	PERMITTED								
	REPORTED								
	PERMITTED								
	REPORTED								
	PERMITTED								

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981. Walnut Creek WWTP transferred reclaimed water for 31 days. ECOLI grabs collected 2X/week. DLY AVG = <1 MPN/100mL; IND GRAB Max = 1 MPN/100mL. E. coli Limits: DLY AVG: 20 / 100mL, IND GRAB: 75 / 100 mL. FCOLI not analyzed.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE		
	<b>Mike Welch</b>	<i>Mike Welch</i>	1   4	0   2	1   2
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR	MO.	DAY
5   1   2	<b>Greg Meszaros, Director</b>	<i>Greg Meszaros</i>	1   4	0   2	1   2
AREA CODE	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR	MO.	DAY
9   7   2			1   4	0   2	1   2

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 2 of 3



<b>40B</b>	<b>WQ0010543-011</b>	<b>01</b>	<b>1   4</b>	<b>0   1</b>	
SYS	PERMIT NUMBER	SET	YEAR	MO.	<b>15651</b>
					EID

THIS REPORT TO BE USED FOR **OTFL 900 RECLAIMED WATER TYPE II**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS			
<b>000085342</b> <b>TRANSFER</b> <b>DAYS MON</b>	REPORTED	0	DAY	0	01	01	
	PERMITTED						
<b>316164024</b> <b>FEC. COLI</b> <b>DLY AVG</b>	REPORTED	0	#/100 ML	0	NA	NA	NA
	PERMITTED	200.000					
<b>316164030</b> <b>FEC. COLI</b> <b>IND GRAB</b>	REPORTED	0	#/100 ML	0	NA	NA	NA
	PERMITTED	800.000					
<b>500507124</b> <b>FLOW</b> <b>DLY AVG</b>	REPORTED	0	MGD	0	NA	NA	NA
	PERMITTED						
<b>800821024</b> <b>BOD CARB</b> <b>DLY AVG</b>	REPORTED	0	MG/L	0	NA	NA	NA
	PERMITTED	15.000					
<b>NUMBER</b> <b>OF OPERATOR</b> <b>CERTIFICATE</b>	REPORTED	WW0018247	NUMBER	0	01		NA
	PERMITTED						
<b>EXPIRATION</b> <b>OF OPERATOR</b> <b>CERTIFICATE</b>	REPORTED	15/11/12	DATE	0	01		NA
	PERMITTED						
<b>CLASS</b> <b>OF OPERATOR</b> <b>CERTIFICATE</b>	REPORTED	A	LETTER	0	01		NA
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	<b>NAME</b>	<b>SIGNATURE</b>	<b>DATE</b>
	<b>Mike Welch</b>		1   4   0   2   1   2
<b>TELEPHONE NUMBER</b>	<b>PLANT OPERATOR</b>	<b>PLANT OPERATOR</b>	<b>YEAR MO. DAY</b>
5   1   2   9   7   2   0   1   0   1	<b>Greg Meszaros, Director</b>		1   4   0   2   1   2
<b>NUMBER</b>	<b>EXECUTIVE OFFICER</b>	<b>EXECUTIVE OFFICER</b>	<b>YEAR MO. DAY</b>

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865

Page 3 of 3



<b>40B</b>	<b>WQ0010543-011</b>	<b>01</b>	<b>1   4</b>	<b>0   1</b>	<b>15652</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OUTFALLS 001 AND RECLAIMED WATER**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

**TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	PERMITTED		VALUE	UNITS			
<b>500507124 FLOW DAILY AVG</b>	REPORTED		46.2	MGD	0	01	01	
	PERMITTED				01	NA	01	NA
<b>NUMBER OF OPERATOR CERTIFICATE</b>	REPORTED		WW0018247	NUMBER	0	01	NA	
	PERMITTED				01	01	NA	NA
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	REPORTED		15/11/12	DATE	0	01	NA	
	PERMITTED				01	01	NA	NA
<b>CLASS OF OPERATOR CERTIFICATE</b>	REPORTED		A	LETTER	0	01	NA	
	PERMITTED				01	01	NA	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

**COMMENTS AND EXPLANATIONS** *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	<b>Mike Welch</b>		1   4   0   2   1   2
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	<b>Greg Meszaros, Director</b>		1   4   0   2   1   2
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

**AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865**



<b>40B</b>	<b>WQ0010543-012</b>	<b>01</b>	<b>1   4   0   1</b>	<b>19743</b>
SYS	PERMIT NUMBER	SET	YEAR   MO.	EID

THIS REPORT TO BE USED FOR **OTFL 800 RECLAIMED WATER TYPE I**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS	NO.	FREQUENCY	TYPE
<b>000085342 TRANSFER DAYS/MON</b>	REPORTED	31	DAY	0	NA	NA	NA
	PERMITTED			11	2/WEEK	03	GRABPKLOAD
<b>316164024 FEC. COLI DLY AVG</b>	REPORTED	NA	#/100 ML	0	NA	NA	NA
	PERMITTED	20.000		11	2/WEEK	03	GRABPKLOAD
<b>316164030 FEC. COLI IND GRAB</b>	REPORTED	NA	#/100 ML	0	NA	NA	NA
	PERMITTED	75.000		11	2/WEEK	03	GRABPKLOAD
<b>500507124 FLOW DLY AVG</b>	REPORTED	1.65	MGD	0	02	CONT	11
	PERMITTED			02	CONT	11	CONT
<b>800821024 BOD CARB DLY AVG</b>	REPORTED	<2.8	MG/L	0	11	2/WEEK	03
	PERMITTED	5.000		11	2/WEEK	03	GRABPKLOAD
<b>820796624 TURBIDITY 30DAYAVG</b>	REPORTED	2.63	NTU	0	11	2/WEEK	03
	PERMITTED	3.000		11	2/WEEK	03	GRABPKLOAD
<b>NUMBER OF OPERATOR CERTIFICATE</b>	REPORTED	WW0011708	NUMBER	0	01		NA
	PERMITTED			01	01		NA
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	REPORTED	15/05/12	DATE	0	01		NA
	PERMITTED			01	01		NA
<b>CLASS OF OPERATOR CERTIFICATE</b>	REPORTED	B	LETTER	0	01		NA
	PERMITTED			01	01		NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

**COMMENTS AND EXPLANATIONS** (Reference all attachments here)  
 Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889. South Austin Regional WWTP transferred reclaimed water for 31 days. ECOLI grabs collected 2/week: DLY AVG = <8 MPN/100mL; IND GRAB Max = 34 MPN/100mL. E. coli Limits: DLY AVG: 20 / 100mL, IND GRAB: 75 / 100 mL. FCOLI not analyzed.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	<b>Randall Swenson</b>		1   4   0   2   1   2
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR   MO.   DAY
5   1   2   9   7   2   0   1   0   1	<b>Greg Meszaros, Director</b>		1   4   0   2   1   2
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR   MO.   DAY

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

## MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	01 SET	1   4 YEAR	0   1 MO.	19742 EID
------------	--------------------------------	-----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR OTFL 900 RECLAIMED WATER TYPE II

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION			NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE	UNITS					
000085342 TRANSFER DAYS/MON	REPORTED	0	DAY	0	01		01	
	PERMITTED					01	NA	01
316164024 FEC. COLI DLY AVG	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	200.000				14	1/WEEK	03
316164030 FEC. COLI IND GRAB	REPORTED	0	#/100 ML	0	NA	NA	NA	NA
	PERMITTED	800.000				14	1/WEEK	03
500507124 FLOW DLY AVG	REPORTED	0	MGD	0	NA	NA	NA	NA
	PERMITTED					14	1/WEEK	12
800821024 BOD CARB DLY AVG	REPORTED	0	MG/L	0	NA	NA	NA	NA
	PERMITTED	15.000				14	1/WEEK	03
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01		NA	
	PERMITTED					01	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	15/05/12	DATE	0	01		NA	
	PERMITTED					01	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01		NA	
	PERMITTED					01	01	NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

	NAME	SIGNATURE	DATE
	Randall Swenson		1   4   0   2   1   2
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5   1   2   9   7   2   0   1   0   1	Greg Meszaros, Director		1   4   0   2   1   2
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087  
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF  
AUSTIN WATER UTILITY  
P.O. BOX 1088  
AUSTIN, TEXAS 78767-8865



<b>40B</b>	<b>WQ0010543-012</b>	<b>01</b>	<b>1   4</b>	<b>0   1</b>	<b>19744</b>
SYS	PERMIT NUMBER	SET	YEAR	MO.	EID

THIS REPORT TO BE USED FOR **COMBINED OTFL 001 AND RECLAIMED WATER**  
**SEE BACK FOR INSTRUCTIONS AND DEFINITIONS**  
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS	YEAR	MO.
<b>500507124</b>							
<b>FLOW</b>	REPORTED						
<b>DAILY AVG</b>	PERMITTED						
<b>NUMBER OF OPERATOR CERTIFICATE</b>	REPORTED						
<b>EXPIRATION OF OPERATOR CERTIFICATE</b>	REPORTED						
<b>CLASS OF OPERATOR CERTIFICATE</b>	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

**COMMENTS AND EXPLANATIONS** *(Reference all attachments here)*

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	<b>Randall Swenson</b>	<i>Randall Swenson</i>	<b>1   4   0   2   1   2</b>
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
<b>5   1   2   9   7   2   0   1   0   1</b>	<b>Greg Meszaros, Director</b>	<i>Greg Meszaros</i>	<b>1   4   0   2   1   2</b>
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY