

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV	Req Mon DAILY MX	03 - MGD								0	Continuous	TOTALZ
					Value NODI													99/99 - Continuous	TM - TOTALZ
					Sample														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.1			=	3.3	19 - mg/L	0	01/01 - Daily	GR - GRAB
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		01/01 - Daily	GR - GRAB
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							=	5	=	9	30 - MPN/100mL	0	02/30 - Twice Per Month	GR - GRAB
					Permit Req.							<=	126 DAILY AV	<=	399 DAILY MX	32 - CFU/100mL		02/30 - Twice Per Month	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	8.8		26 - lb/d			=	3.1	=	5.1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV		26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

Ecoli: Units reported in MPN/100 mL, not CFU/100 mL.

Attachments

No attachments.

Report Last Saved By**AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov
 Name: Jane Burazer
 E-Mail: jane.burazer@austintexas.gov

Date/Time: 2015-05-13 19:15 (Time Zone: -05:00)