

DMR Copy of Record

Permit

Permit #: TX0034207

Major:

Permittee: AUSTIN, CITY OF

Permittee Address:	10502 MELLOW MEADOW DR AUSTIN, TX 78750
---------------------------	--

Facility: ANDERSON MILL MUD WWTP

Facility Location:	10502 MELLOW MEADOW PKWY WILLIAMSON COUNTY AUSTIN, TX 78750
---------------------------	---

Permitted Feature:	001 External Outfall
---------------------------	-------------------------

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Report Dates & Status

Monitoring Period: From 08/01/15 to 08/31/15

DMR Due Date: 09/20/15

Status: NetDMR Validated & Complete

Considerations for Form Completion

Principal Executive Officer

First Name: Greg

Title:	Director
---------------	----------

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	MGD	03 - MGD							0	Continuous	TOTALZ
					Value NODI														99/99 - Continuous	TM - TOTALZ
					Sample															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.1			=	3.8	19 - mg/L		0	01/01 - Daily	GR - GRAB
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L			01/01 - Daily	GR - GRAB
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							=	6	=	37	30 - MPN/100mL		0	02/30 - Twice Per Month	GR - GRAB
					Permit Req.							<=	126 DAILY AV	<=	399 DAILY MX	3Z - CFU/100mL			02/30 - Twice Per Month	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	11.7			26 - lb/d		=	3.4	=	4	19 - mg/L		0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L			01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

Ecoli: Units reported in MPN/100 mL, not CFU/100 mL.

Attachments

No attachments.

Report Last Saved By**AUSTIN, CITY OF**

User: jane.burazer@austintexas.gov

Name: Jane Burazer

E-Mail: jane.burazer@austintexas.gov

Date/Time:

2015-09-15 18:13 (Time Zone: -05:00)